

UL Online Certifications Directory

CEYY.R18795 Outlet Boxes and Fittings Classified for Fire Resistance

[Page Bottom](#)

Outlet Boxes and Fittings Classified for Fire Resistance

[See General Information for Outlet Boxes and Fittings Classified for Fire Resistance](#)

CANTEX INC

R18795

SUITE 2700

301 COMMERCE ST

FORT WORTH, TX 76102 USA

Types EZ18CN, EZ18CNG, EZ20CH, EZ20CHG, EZ20CN, EZ20CNG nonmetallic outlet boxes intended for fixture support. For use in the ceiling of fire resistance floor-ceiling assemblies constructed with wood joists, wood flooring and gypsum wallboard ceilings with 2 hr or less classification periods. Clearance between boxes and cutouts in ceiling shall not exceed 1/8 in. The area of openings for boxes shall not aggregate more than 31.0 sq in. per 100 sq ft of ceiling area with no opening exceeding 13.0 sq in. No box shall be located within 4.5 ft of another box.

Types EZ14SO, EZ16SN, EZ18SN, EZ18SNZ, EZ18XN, EZ20SN, EZ20SB, EZ20SBV, EZ20SNZ, EZ23SN, EZ23SNZ, EZ25DO, EZ32DN, EZ32DNZ, EZ32XN, EZ44TN, EZ44TNZ, EZ48TN, EZ74TN, EZ18CN, EZ18CNG, EZ20CH, EZ20CHG, EZ20CN and EZ20CNG, nonmetallic outlet boxes. For use in fire resistance walls constructed of wood or nonbearing steel studs and gypsum wallboard with 2 hrs or less classification periods. Clearance between boxes and cutouts in wall shall not exceed 1/8 in. The area of openings for boxes shall not aggregate more than 100 sq in. per 100 sq ft of wall or partition area with no opening exceeding 22.0 sq. in. Outlet boxes on opposite sides of wall or partition shall be separated by a horizontal distance of not less than 24 in.

Types EZ14SO, EZ16SN, EZ18CO, EZ18COG, EZ18SN, EZ18XN, EZ20SN, EZ23SN nonmetallic outlet boxes not intended for fixture support. For use in fire resistance floor-ceiling assemblies constructed with wood joists, wood flooring and gypsum wallboard ceilings with 2 hr or less classification periods. Clearance between boxes and cutouts in ceiling shall not be exceed 1/8 in. The area of openings for boxes shall not aggregate more than 31.0 sq in. per 100 sq ft of ceiling area with no opening exceeding 9.75 sq in. No box shall be located within 4.5 ft of another box.

Types EZ03SXA, EZ06DXA, EZXKL, EZYKL covers and extension rings intended for use with 4 in. diam or square ceiling or wall outlet and switch boxes.

Types EZ03YC, EZ04YC, EZ08ED, EZ09ED, EZ04ES, EZ05ES, EZ06ES, EZ08ES, EZYL1 nonmetallic box exteners for use with nonmetallic boxes described above.

The boxes shall be installed in compliance with the National Electrical Code.

[Last Updated](#) on 2006-06-05

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2006 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

