



- POWER PLAN NOTES:**
1. PROVIDE 20 AMP DEDICATED EDISON CIRCUITS FOR THREE MIXER POSITIONS, AUDIO, VIDEO, AND LIGHTING.
 2. PROVIDE THREE 20 AMP DEDICATED CIRCUITS FOR BAND MONITORS, REAR OF BAND STAGE.
 3. PROVIDE TWO 20 AMP DEDICATED CIRCUIT FOR STAGE MONITORS, CENTER STAGE.
 4. PROVIDE FOUR EACH 20 AMP DEDICATED EDISON CIRCUITS PER AUDIO EQUIPMENT ROOM.
 5. T.V. RECEPTACLE, VERIFY MOUNTING HEIGHT WITH OWNER.

POWER PLAN
SCALE: 1/8"=1'-0"

POWER PLAN LEGEND

SYMBOL	DESCRIPTION	CONVENTIONS
⊖	STANDARD 120V 2-PHASE RECEPTACLE @ 1'Ø AIR (UNLESS NOTED)	
⊖	DEDICATED RECEPTACLE SEE PANEL SCHEDULE FOR CIRCUIT SIZE	
⊖	OH RECEPTACLE	ALL OUTLETS WITHIN 40' OF A WATER SOURCE SHALL BE OH
⊖	HEATER RANGE 120V 3-PHASE RECEPT. @ 3Ø AIR (UNLESS NOTED)	
⊖	RECEPTACLE @ 6' ABOVE COUNTER	
⊖	STANDARD 220V DUPLEX RECEPTACLE @ 1'Ø AIR (UNLESS NOTED)	
⊖	STANDARD 120V DUPLEX RECEPTACLE @ 1'Ø AIR (UNLESS NOTED)	
⊖	STANDARD 120V DUPLEX RECEPTACLE ABOVE CEILING	
⊖	QUAD CAT 5 JACKS WITH FACE-AT NETWORKING CONNECTION	
⊖	POWER DISCONNECT	
⊖	ELECTRIC WATER HEATER	
⊖	AIR CONDITIONING COND. UNIT SEE MECH SHEETS FOR UNIT DETAILS	

NOTES:
1. CONNECT ALL DISCONNECTS TO NEAREST COMPLIANT POWER SOURCE.

- EQUIPMENT NOTES:**
1. EQUIPMENT LAYOUT, ELECTRICAL AND MECHANICAL DETAILS ARE BASED ON THE INFORMATION PROVIDED BY THE OWNER. CONTRACTOR TO COORDINATE ANY CORRESPONDING CHANGES TO EQUIPMENT SELECTION, LAYOUT, MECHANICAL, AND ELECTRICAL REQUIREMENTS WITH THE OWNER.
 2. CONTRACTOR TO COORDINATE EQUIPMENT REQUIREMENTS WITH ARCHITECTURAL, MECHANICAL, AND PLUMBING DISCIPLINES.
 3. SMOKE DETECTORS SHALL NOT BE INSTALLED CLOSER THAN 1'-0" TO A LIGHT FIXTURE OR WITHIN 3'-0" FROM A HVAC AHU/RU AIR SUPPLY DIFFUSER.
 4. MECHANICAL EXHAUST FAN SUPPLIED BY MECHANICAL CONTRACTOR.
 5. PROVIDE 3/4" EXIT AT ALL DATA JACKS TO ROOF OR CEILING ABOVE.

ELECTRICAL NOTES

1. ALL WORK SHALL CONFORM TO THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE, THE GOVERNING ELECTRICAL CODE AND ALL OTHER INSPECTION DEPARTMENT'S HAVING JURISDICTION. OBTAIN CERTIFICATES OR APPROVAL WHERE REQUIRED.
2. ALL MATERIALS FINISHED SHALL BE NEW AND SHALL BE UL LISTED.
3. THE EXHAUST ANCHORAGE AND SECURING OF ALL EXHAUST PIPING SHALL NOT BE USED, ETC. SHALL BE DETERMINED BY ACTUAL CONDITIONS IN THE FIELD.
4. PRIOR TO BIDDING, CONTRACTOR SHALL VISIT THE JOB SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS.
5. ELECTRICAL CONTRACTOR SHALL COORDINATE HIS WORK WITH OTHER TRADES AND WITH OTHER CONTRACTORS WHOSE WORK MAY AFFECT THIS INSTALLATION.
6. ELECTRICAL CONTRACTOR SHALL COORDINATE THE NEARBY ELECTRICAL SERVICE WITH UTILITY COMPANY AND WHERE MORE THAN ONE SWITCH OCCURS IN THE SAME LOCATION, THEY SHALL BE INSTALLED IN A GANG TYPE BOX UNDER ONE COVER PLATE.
7. ELECTRICAL CONTRACTOR SHALL COORDINATE THE TELEPHONE INSTALLATION WITH THE TELEPHONE COMPANY AND THE GENERAL CONTRACTOR.
8. INTERFERE WITH CLEARANCES REQUIRED FOR FINISHED CEILING, PLASTER PARTITIONS, LATER DESIGNERS THAT SUCH DETAILS OR DESIGN CANNOT BE FOLLOWED, THE CONTRACTOR AT HIS OWN EXPENSE, SHALL MAKE SUCH CHANGES IN THE WORK AS DIRECTED BY THE ARCHITECT, AS WELL AS TO PERFORM A TEST REQUIRED BY THE OWNER OR THE ENGINEER IN CONNECTION WITH THE OPERATION OF THE ELECTRICAL SYSTEM IN THE BUILDING.
9. ALL TESTS SHALL BE MADE IN ACCORDANCE WITH THE LATEST STANDARD OF THE IEEE AND THE NATIONAL ELECTRICAL CODE.
10. MINIMUM CONDUCTOR SIZE SHALL BE #12 GROUND INSULATION. MINIMUM SIZE CONDUIT SHALL BE 3/4" EXIT FOR INTERIOR USE, AND 3/4" RIGID ALUMINUM FOR EXTERIOR USE. USE THE NMC CABLE COPPER FOR LIGHTS AND RECEPTACLE CIRCUITS. EXTERIOR FITTINGS SHALL BE CAST BOXES AND COVERS. INTERIOR FITTINGS SHALL BE CAST WHERE EXPOSED ON WALLS. STAMPED BOXES MAY BE USED ABOVE CEILING IN AIR CONDITIONED SPACES, WHERE LAY IN FIXTURES ARE IN USE. USE 1/4" 2 ALLOWED FOR 6" WIDTH.
11. CONTRACTOR SHALL INSTALL WIRING AND OTHER CIRCUIT COMPONENTS TO MATCH EQUIPMENT ACTUALLY INSTALLED.
12. INSTALL GROUND FAULT RECEPTACLES AT RECEPTACLE LOCATIONS WITHIN 5' OF SINKS OR LAVATORIES, AND AT EXTERIOR LOCATIONS. EXTERIOR RECEPTACLES SHALL ALSO BE WATERPROOF.
13. BONDING AND GROUNDING SHALL BE IN ACCORDANCE WITH NFPA 70:250.43, NFPA 250:23, 250:71 & 250:72.
14. GROUND NEUTRAL IN ACCORDANCE WITH NFPA 70:250.235.
15. PROTECT SHALL BE THE CLASS 95, 250V VOLT, 200,000 AMP INTERRUPTING CAPABILITY.
16. SYSTEM TO MEET REQUIREMENTS OF THE STATE FIRE MARSHAL.
17. EXTERIOR LIGHTING SHALL BE SHADDED OR INWARDLY DIRECTED IN SUCH A MANNER SO THAT NO DIRECT LIGHTING OR GLARE IS CAST BEYOND THE PROPERTY LINE. THE INTENSITY OF SUCH LIGHTING SHALL NOT EXCEED ONE FOOT CANDLE AS MEASURED AT THE ADJUTING PROPERTY LINE.
18. ALL ELECTRICAL, MECHANICAL AND PLUMBING PENETRATING FIRE PARTITIONS SHALL BE FIRE CAULKED (PENETRATIONS THROUGH RATED AND PLUMBING PENETRATING FIRE PARTITIONS SHALL BE FIRE CAULKED ACCORDANCE WITH NFPA 70:310.15).
19. PENETRATIONS THROUGH RATED AND PLUMBING PENETRATING FIRE PARTITIONS SHALL BE FIRE CAULKED ACCORDANCE WITH NFPA 70:310.15).

DAMMON ENGINEERING, INC.
 CHIEF ENGINEER
 EMMETT DAMMON, P.E.
 CHIEF ARCHITECT
 ROBERT WILTSE

554 OLD SPANISH TRAIL
 SUDELL, LA. 70458
 OFFICE: 985-649-5832
 FAX: 985-641-5950

WEBSITE:
 WWW.DAMMONENGINEERING.COM
 EMAIL:
 DAMMONENG@BELLOUTH.NET

ARCHITECTURE
 ENGINEERING
 STUDIES
 PLANNING
 INVESTIGATION
 EXPERT WITNESS

LIVING THE WORD
 INTERNATIONAL

2528
 OLD SPANISH TRAIL
 SUDELL, LA
 70461

POWER
 PLAN

REV: _____

SCALE: AS NOTED

JOB#: 2128

DATE: 01-27-12

SHEET 11

E-1

OF 15