

PANEL: MDP
 LOCATION: ELEC. RM. 123
 FEEDER SOURCE: UTILITY CO.

VOLTAGE: 120/208V, 800A, 3Ø, 4W, W/ MAIN BRKs
 ENCLOSURE: SURFACE MOUNTED WEQUIPMENT GND BAR
 BOLT-ON BRK 22000 AC

CCT NO.	THRU WIRE SIZE	JOB DESCRIPTION	BREAKER	TO/E	AMP	VOLT	4Ø 3Ø CO		TO/E	AMP	JOB DESCRIPTION	THRU WIRE SIZE	CCT NO.
							Ø4	Ø3					
1	#1.2	AHU #1 1.5 TON 2.3 KW E.C. HEAT	3	110	3	7070	Ø4	Ø3	3	110	AHU #4 1.5 TON 2.3 KW E.C. HEAT	#2	4
5	#2	AHU #2 1.8 KW E.C. HEAT	3	90	3	5690	Ø4	Ø3	3	90	AHU #3 1.8 KW E.C. HEAT	#3	10
7	#3	AHU #5 1.9 KW E.C. HEAT	3	90	3	5690	Ø4	Ø3	3	90	AHU #6 1.9 KW E.C. HEAT	#3	12
13	#1.2	AHU #5 5 TON 1.9 KW E.C. HEAT	3	35	3	2430	Ø4	Ø3	3	35	AHU #9 5 TON 1.5 KW E.C. HEAT	#1.0	22
15	#1.0	AHU #6 4 TON 1.0 KW E.C. HEAT	3	30	3	2000	Ø4	Ø3	3	30	AHU #7 7.5 TON 1.8 KW E.C. HEAT	#1.0	24
17	#1.0	AHU #7 7.5 TON 1.8 KW E.C. HEAT	3	90	3	5690	Ø4	Ø3	3	90	SPACE	SPACE	42
25	#3	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	36
27	#3	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	34
29	#3	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	32
31	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	30
33	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	28
35	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	26
37	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	24
39	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	22
41	#3.0	SPACE	3	225	3	30080	Ø4	Ø3	3	225	SPACE	SPACE	20

PANEL: LP-1
 LOCATION: ELEC. RM. 123
 FEEDER SOURCE: MDP

VOLTAGE: 208/120V, 200A, 3Ø, 4W, W/ ILO
 ENCLOSURE: SURFACE MOUNTED WEQUIPMENT GND BAR
 BOLT-ON BRK 22000 AC

CCT NO.	THRU WIRE SIZE	JOB DESCRIPTION	BREAKER	TO/E	AMP	VOLT	4Ø 3Ø CO		TO/E	AMP	JOB DESCRIPTION	THRU WIRE SIZE	CCT NO.
							Ø4	Ø3					
1	#1.2	LIGHTING RV: 1.21, 1.22, 1.23	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING RV: 1.13, 1.14, 1.15, 1.16, 1.17	#1.2	2
3	#1.2	LIGHTING RV: 1.18	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING RV: 1.28, 1.30, 1.31	#1.2	4
5	#1.2	LIGHTING RV: 1.00	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING RV: 1.27	#1.2	6
7	#1.2	LIGHTING RV: 1.25	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING RV: 1.05, 1.06, 1.07, 1.08, 1.24, 1.25	#1.2	8
9	#1.2	LIGHTING RV: 1.25	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING RV: 1.01, 1.02, CRV ROOMS ON PHOTO	#1.2	10
11	#1.2	LIGHTING WEST WALL, JMW	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING WEST WALL, JMW	#1.2	12
13	#1.2	LIGHTING EAST WALL, JMW	20	1	1600	Ø4	Ø3	20	1	1600	LIGHTING EAST WALL, JMW	#1.2	14
15	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	16
17	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	18
19	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	20
21	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	22
23	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	24
25	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	26
27	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	28
29	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	30
31	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	32
33	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	34
35	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	36
37	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	38
39	#1.2	RECEPTACLES	20	1	1600	Ø4	Ø3	20	1	1600	RECEPTACLES	#1.2	40
41	#1.2	SPACE	20	1	1600	Ø4	Ø3	20	1	1600	SPACE	#1.2	42

PANEL: PP-1
 LOCATION: ELEC. RM. 123
 FEEDER SOURCE: MDP


VOLTAGE: 208/120V, 225A, 3Ø, 4W, W/ ILO
 ENCLOSURE: SURFACE MOUNTED WEQUIPMENT GND BAR
 BOLT-ON BRK 22000 AC

CCT NO.	THRU WIRE SIZE	JOB DESCRIPTION	BREAKER	TO/E	AMP	VOLT	4Ø 3Ø CO		TO/E	AMP	JOB DESCRIPTION	THRU WIRE SIZE	CCT NO.
							Ø4	Ø3					
1	#1.2	CU #1 1.5 TON	3	60	3	4350	Ø4	Ø3	3	60	CU #4 1.5 TON	#4	4
5	#1.2	CU #2 7.5 TON	3	50	3	2390	Ø4	Ø3	3	50	CU #3 7.5 TON	#6	6
7	#1.2	CU #5 5 TON	3	35	3	1450	Ø4	Ø3	3	35	CU #6 5 TON	#1.0	22
13	#1.0	CU #6 4 TON	3	30	3	1250	Ø4	Ø3	3	30	CU #7 7.5 TON	#1.0	24
15	#1.0	CU #7 7.5 TON	3	90	3	2390	Ø4	Ø3	3	90	W/SD FROST OUT	#1.2	26
17	#1.0	CU #8 4 TON	3	30	3	1250	Ø4	Ø3	3	30	W/SD FROST OUT	#1.2	28
19	#1.0	CU #9 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	30
21	#1.0	CU #10 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	32
23	#1.0	CU #11 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	34
25	#1.0	CU #12 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	36
27	#1.0	CU #13 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	38
29	#1.0	CU #14 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	40
31	#1.0	CU #15 5 TON	3	35	3	1450	Ø4	Ø3	3	35	SPACE	#1.2	42

PANEL: LP-2
 LOCATION: ELEC. RM. 123
 FEEDER SOURCE: MDP

VOLTAGE: 208/120V, 225A, 3Ø, 4W, W/ ILO
 ENCLOSURE: SURFACE MOUNTED WEQUIPMENT GND BAR
 BOLT-ON BRK 22000 AC

CCT NO.	THRU WIRE SIZE	JOB DESCRIPTION	BREAKER	TO/E	AMP	VOLT	4Ø 3Ø CO		TO/E	AMP	JOB DESCRIPTION	THRU WIRE SIZE	CCT NO.
							Ø4	Ø3					
1	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	2
3	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	4
5	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	6
7	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	8
9	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	10
11	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	12
13	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	14
15	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	16
17	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	18
19	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	20
21	#1.2	SAINTURRY LIGHTING	20	1	1600	Ø4	Ø3	20	1	1600	SAINTURRY LIGHTING	#1.2	22
23	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	24
25	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	26
27	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	28
29	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	30
31	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	32
33	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	34
35	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	36
37	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	38
39	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	40
41	#1.2	STAGE MONITOR	20	1	1600	Ø4	Ø3	20	1	1600	STAGE MONITOR	#1.2	42



DAMMON
 ENGINEERING, INC.
 CHIEF ENGINEER
 EMMETT
 DAMMON, P.E.
 CHIEF ARCHITECT
 ROBERT
 WILTSE

554 OLD SPANISH TRAIL
 SUDELL, LA, 70458
 OFFICE: 985-649-5832
 FAX: 985-641-5950
 WEBSITE:
 WWW.DAMMONENGINEERING.COM
 EMAIL:
 DAMMONENG@BELL-SOUTH.NET

ARCHITECTURE
 ENGINEERING
 STUDIES
 PLANNING
 INVESTIGATION
 EXPERT WITNESS

LIVING THE WORD
 INTERNATIONAL

25228
 OLD SPANISH TRAIL
 SUDELL, LA
 70461

PANEL
 SCHEDULES

REV:
 SCALE: AS NOTED
 JOB#: 2128
 DATE: 01-27-12
 SHEET 13

E-3
 OF 15