



Envelope Compliance Certificate

2006 IECC

Section 1: Project Information

Project Type: **New Construction**
Project Title : STARC West Residential Community Home

Construction Site:
1705 Viola Street
Mandeville, LA

Owner/Agent:

Designer/Contractor:
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: General Information

Building Location (for weather data): **Mandeville, Louisiana**
Climate Zone: **2a**
Building Type for Envelope Requirements: **Non-Residential**
Vertical Glazing / Wall Area Pct.: **9%**

Activity Type(s) **Floor Area**
Multifamily 5100

Section 3: Requirements Checklist

Envelope PASSES: Design 15% better than code.

Climate-Specific Requirements:

| Component Name/Description | Gross Area or Perimeter | Cavity R-Value | Cont. R-Value | Proposed U-Factor | Budget U-Factor ^(a) |
|--|-------------------------|----------------|---------------|-------------------|--------------------------------|
| Roof 1: Metal Building, Standing Seam | 5100 | 30.0 | 30.0 | 0.020 | 0.065 |
| Exterior Wall 1: Wood-Framed, 16" o.c. | 2350 | 19.0 | 19.0 | 0.028 | 0.089 |
| Window 1: Metal Frame:Double Pane with Low-E, Tinted, SHGC 0.05, PF 2.00 | 221 | --- | --- | 1.000 | 0.750 |
| Door 1: Insulated Metal, Swinging | 120 | --- | --- | 1.000 | 0.700 |

(a) Budget U-factors are used for software baseline calculations ONLY, and are not code requirements.

Air Leakage, Component Certification, and Vapor Retarder Requirements:

- 1. All joints and penetrations are caulked, gasketed or covered with a moisture vapor-permeable wrapping material installed in accordance with the manufacturer's installation instructions.
- 2. Windows, doors, and skylights certified as meeting leakage requirements.
- 3. Component R-values & U-factors labeled as certified.
- 4. No roof insulation is installed on a suspended ceiling with removable ceiling panels.
- 5. 'Other' components have supporting documentation for proposed U-Factors.
- 6. Insulation installed according to manufacturer's instructions, in substantial contact with the surface being insulated, and in a manner that achieves the rated R-value without compressing the insulation.
- 7. Stair, elevator shaft vents, and other outdoor air intake and exhaust openings in the building envelope are equipped with motorized dampers.
- 8. Cargo doors and loading dock doors are weather sealed.
- 9. Recessed lighting fixtures are: (i) Type IC rated and sealed or gasketed; or (ii) installed inside an appropriate air-tight assembly with a 0.5 inch clearance from combustible materials and with 3 inches clearance from insulation material.

Note: Vapor retarder not required in this location.

Section 4: Compliance Statement

Compliance Statement: The proposed envelope design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed envelope system has been designed to meet the 2006 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

EMMETT DAMMON
Name - Title


Signature

6-10-11
Date



COMcheck Software Version 3.8.1

Interior Lighting Compliance Certificate

2006 IECC

Section 1: Project Information

Project Type: **New Construction**

Project Title : STARC West Residential Community Home

Construction Site:
1705 Viola Street
Mandeville, LA

Owner/Agent:

Designer/Contractor:

Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: Interior Lighting and Power Calculation

| A Area Category | B Floor Area (ft ²) | C Allowed Watts / ft ² | D Allowed Watts (B x C) |
|-----------------------|---------------------------------------|---|-------------------------------|
| Multifamily | 5100 | 0.7 | 3570 |
| Total Allowed Watts = | | | 3570 |

Section 3: Interior Lighting Fixture Schedule

| A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast | B Lamps/ Fixture | C # of Fixtures | D Fixture Watt. | E (C X D) |
|---|------------------------|-----------------------|-----------------------|--------------|
| Multifamily (5100 sq.ft.) | | | | |
| Compact Fluorescent 1: Twin Tube 50W / Magnetic | 4 | 34 | 20 | 680 |
| Incandescent 1: Incandescent 65W | 4 | 6 | 25 | 150 |
| Total Proposed Watts = | | | | 830 |

Section 4: Requirements Checklist

Lighting Wattage:

1. Total proposed watts must be less than or equal to total allowed watts.

| Allowed Watts | Proposed Watts | Complies |
|---------------|----------------|----------|
| 3570 | 830 | YES |

Controls, Switching, and Wiring:

2. Independent controls for each space (switch/occupancy sensor).

Exceptions:

- Areas designated as security or emergency areas that must be continuously illuminated.
- Lighting in stairways or corridors that are elements of the means of egress.
3. Master switch at entry to hotel/motel guest room.
4. Individual dwelling units separately metered.
5. Each space required to have a manual control also allows for reducing the connected lighting load by at least 50 percent by either controlling all luminaires, dual switching of alternate rows of luminaires, alternate luminaires, or alternate lamps, switching the middle lamp luminaires independently of other lamps, or switching each luminaire or each lamp.

Exceptions:

- Only one luminaire in space.
- An occupant-sensing device controls the area.
- The area is a corridor, storeroom, restroom, public lobby or sleeping unit.
- Areas that use less than 0.6 Watts/sq.ft.
- 6. Automatic lighting shutoff control in buildings larger than 5,000 sq.ft.

Exceptions:

- Sleeping units, patient care areas; and spaces where automatic shutoff would endanger safety or security.
- 7. Photocell/astronomical time switch on exterior lights.

Exceptions:

- Lighting intended for 24 hour use.
- 8. Tandem wired one-lamp and three-lamp ballasted luminaires (No single-lamp ballasts).

Exceptions:


- Electronic high-frequency ballasts; Luminaires on emergency circuits or with no available pair.

Interior Lighting PASSES: Design 77% better than code.

Section 5: Compliance Statement

Compliance Statement: The proposed lighting design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed lighting system has been designed to meet the 2006 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

EMMETT DANNON
Name - Title


Signature

6-10-11
Date



COMcheck Software Version 3.8.1

Exterior Lighting Compliance Certificate

2006 IECC

Section 1: Project Information

Project Type: **New Construction**

Project Title : STARC West Residential Community Home

Construction Site:
1705 Viola Street
Mandeville, LA

Owner/Agent:

Designer/Contractor:

Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: Exterior Lighting Area/Surface Power Calculation

| A Exterior Area/Surface | B Quantity | C Allowed Watts / Unit | D Tradable Wattage | E Allowed Watts (B x C) | F Proposed Watts |
|----------------------------------|-------------------------|---------------------------------|--------------------------|--------------------------------------|------------------------|
| walkway (Walkway < 10 feet wide) | 50 ft of walkway length | 1 | Yes | 50 | 45 |
| | | | | Total Tradable Watts* = | 50 |
| | | | | Total Allowed Watts = | 50 |
| | | | | Total Allowed Supplemental Watts** = | 3 |

* Wattage tradeoffs are only allowed between tradable areas/surfaces.

** A supplemental allowance equal to 5% of total allowed wattage may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Section 3: Exterior Lighting Fixture Schedule

| A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast | B Lamps/ Fixture | C # of Fixtures | D Fixture Watt. | E (C X D) | |
|---|------------------------|-----------------------|-----------------------|---------------------------------|----|
| walkway (Walkway < 10 feet wide 50 ft of walkway length): Tradable Wattage | | | | | |
| Incandescent 1: Incandescent 50W | 1 | 3 | 15 | 45 | |
| | | | | Total Tradable Proposed Watts = | 45 |

Section 4: Requirements Checklist

Lighting Wattage:

1. Within each non-tradable area/surface, total proposed watts must be less than or equal to total allowed watts. Across all tradable areas/surfaces, total proposed watts must be less than or equal to total allowed watts.

Compliance: Passes.

Controls, Switching, and Wiring:

2. All exemption claims are associated with fixtures that have a control device independent of the control of the nonexempt lighting.
3. All lighting fixtures are controlled by a photosensor or astronomical time switch that is capable of automatically turning off the fixture when sufficient daylight is available or the lighting is not required.

Exceptions:

- Covered vehicle entrance/exit areas requiring lighting for safety, security and eye adaptation.

Exterior Lighting Efficacy:

4. All exterior building grounds luminaires that operate at greater than 100W have minimum efficacy of 60 lumen/watt.

Exceptions:

- Controlled by motion sensor or exempt from consideration under the provisions of Section 505.6.2.

Exterior Lighting PASSES: Design 14% better than code.

Section 5: Compliance Statement

Compliance Statement: The proposed exterior lighting design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed lighting system has been designed to meet the 2006 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

EMMETT DAMMON
Name - Title


Signature

6-10-11
Date



COMcheck Software Version 3.8.1

Mechanical Compliance Certificate

2006 IECC

Section 1: Project Information

Project Type: **New Construction**

Project Title : STARC West Residential Community Home

Construction Site:
1705 Viola Street
Mandeville, LA

Owner/Agent:

Designer/Contractor:

Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: General Information

Building Location (for weather data):
Climate Zone:

Mandeville, Louisiana
2a

Section 3: Mechanical Systems List

Quantity System Type & Description

- | | |
|---|--|
| 1 | HVAC System 1 (Single Zone) : Heating: 1 each - Central Furnace, Electric, Capacity = 17 kBtu/h Cooling: 1 each - Split System, Capacity = 72 kBtu/h, Efficiency = 15.00 EER, Air-Cooled Condenser |
|---|--|

Section 4: Requirements Checklist

Requirements Specific To: HVAC System 1 :

1. Equipment minimum efficiency: Split System: 10.3 EER

Generic Requirements: Must be met by all systems to which the requirement is applicable:

1. Load calculations per ASHRAE Fundamentals
2. Plant equipment and system capacity no greater than needed to meet loads
- Exception: Standby equipment automatically off when primary system is operating
 - Exception: Multiple units controlled to sequence operation as a function of load
3. Minimum one temperature control device per system
4. Minimum one humidity control device per installed humidification/dehumidification system
5. Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2-hour occupant override, 10-hour backup
- Exception: Continuously operating zones
 - Exception: 2 kW demand or less, submit calculations
6. Outside-air source for ventilation; system capable of reducing OSA to required minimum
7. R-5 supply and return air duct insulation in unconditioned spaces
R-8 supply and return air duct insulation outside the building
R-8 insulation between ducts and the building exterior when ducts are part of a building assembly
- Exception: Ducts located within equipment
 - Exception: Ducts with interior and exterior temperature difference not exceeding 15°F.
8. Mechanical fasteners and sealants used to connect ducts and air distribution equipment
9. Ducts sealed - longitudinal seams on rigid ducts; transverse seams on all ducts; UL 181A or 181B tapes and mastics
10. Hot water pipe insulation: 1 in. for pipes <=1.5 in. and 2 in. for pipes >1.5 in.
Chilled water/refrigerant/brine pipe insulation: 1 in. for pipes <=1.5 in. and 1.5 in. for pipes >1.5 in.

Steam pipe insulation: 1.5 in. for pipes ≤ 1.5 in. and 3 in. for pipes > 1.5 in.

- Exception: Piping within HVAC equipment.
- Exception: Fluid temperatures between 55 and 105°F.
- Exception: Fluid not heated or cooled with renewable energy.
- Exception: Runouts < 4 ft in length.
- 11. Operation and maintenance manual provided to building owner
- 12. Thermostatic controls have 5°F deadband
 - Exception: Thermostats requiring manual changeover between heating and cooling
 - Exception: Special occupancy or special applications where wide temperature ranges are not acceptable and are approved by the authority having jurisdiction.
- 13. Balancing devices provided in accordance with IMC (2006) 603.17
- 14. Motorized, automatic shutoff dampers required on exhaust and outdoor air supply openings
 - Exception: Gravity dampers acceptable in buildings < 3 stories
 - Exception: Gravity dampers acceptable in systems with outside or exhaust air flow rates less than 300 cfm where dampers are interlocked with fan
- 15. Exhaust air heat recovery included for systems 5,000 cfm or greater with more than 70% outside air fraction or specifically exempted
 - Exception: Systems serving spaces that are not cooled and heated to $< 60^\circ\text{F}$.
 - Exception: Commercial kitchen hoods (grease) classified as Type 1 by NFPA 96.
 - Exception: Systems exhausting toxic, flammable, paint, or corrosive fumes or dust.
 - Exception: Where the largest exhaust source is less than 75% of the design outdoor airflow.
 - Exception: Systems requiring dehumidification that employ energy recovery in series with the cooling coil.

Section 5: Compliance Statement

Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 2006 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

EMMETT DAMMON  6-10-11
Name - Title Signature Date



Mechanical Requirements Description

2006 IECC

The following list provides more detailed descriptions of the requirements in Section 4 of the Mechanical Compliance Certificate.

Requirements Specific To: HVAC System 1 :

1. The specified heating and/or cooling equipment is covered by the ASHRAE 90.1 Code and must meet the following minimum efficiency:
Split System: 10.3 EER

Generic Requirements: Must be met by all systems to which the requirement is applicable:

1. Design heating and cooling loads for the building must be determined using procedures in the ASHRAE Handbook of Fundamentals or an approved equivalent calculation procedure.
2. All equipment and systems must be sized to be no greater than needed to meet calculated loads. A single piece of equipment providing both heating and cooling must satisfy this provision for one function with the capacity for the other function as small as possible, within available equipment options.
 - Exception: The equipment and/or system capacity may be greater than calculated loads for standby purposes. Standby equipment must be automatically controlled to be off when the primary equipment and/or system is operating.
 - Exception: Multiple units of the same equipment type whose combined capacities exceed the calculated load are allowed if they are provided with controls to sequence operation of the units as the load increases or decreases.
3. Each heating or cooling system serving a single zone must have its own temperature control device.
4. Each humidification system must have its own humidity control device.
5. The system or zone control must be a programmable thermostat or other automatic control meeting the following criteria:
 - a) capable of setting back temperature to 55°F during heating and setting up to 85°F during cooling,
 - b) capable of automatically setting back or shutting down systems during unoccupied hours using 7 different day schedules,
 - c) have an accessible 2-hour occupant override,
 - d) have a battery back-up capable of maintaining programmed settings for at least 10 hours without power.
 - Exception: A setback or shutoff control is not required on thermostats that control systems serving areas that operate continuously.
 - Exception: A setback or shutoff control is not required on systems with total energy demand of 2 kW (6,826 Btu/h) or less.
6. The system must supply outside ventilation air as required by Chapter 4 of the International Mechanical Code. If the ventilation system is designed to supply outdoor-air quantities exceeding minimum required levels, the system must be capable of reducing outdoor-air flow to the minimum required levels.
7. Air ducts must be insulated to the following levels:
 - a) Supply and return air ducts for conditioned air located in unconditioned spaces (spaces neither heated nor cooled) must be insulated with a minimum of R-5. Unconditioned spaces include attics, crawl spaces, unheated basements, and unheated garages.
 - b) Supply and return air ducts and plenums must be insulated to a minimum of R-8 when located outside the building.
 - c) When ducts are located within exterior components (e.g., floors or roofs), minimum R-8 insulation is required only between the duct and the building exterior.
 - Exception: Duct insulation is not required on ducts located within equipment.
 - Exception: Duct insulation is not required when the design temperature difference between the interior and exterior of the duct or plenum does not exceed 15°F.
8. Mechanical fasteners and seals, mastics, or gaskets must be used when connecting ducts to fans and other air distribution equipment, including multiple-zone terminal units.
9. All joints, longitudinal and transverse seams, and connections in ductwork must be securely sealed using weldments; mechanical fasteners with seals, gaskets, or mastics; mesh and mastic sealing systems; or tapes. Tapes and mastics must be listed and labeled in accordance with UL 181A and shall be marked '181A-P' for pressure sensitive tape, '181A-M' for mastic or '181A-H' for heat-sensitive tape. Tapes and mastics used to seal flexible air ducts and flexible air connectors shall comply with UL 181B and shall be marked '181B-FX' for pressure-sensitive tape or '181B-M' for mastic. Unlisted duct tape is not permitted as a sealant on any metal ducts.
10. All pipes serving space-conditioning systems must be insulated as follows:
 - Hot water piping for heating systems:
 - 1 in. for pipes \leq 1 1/2-in. nominal diameter,
 - 2 in. for pipes $>$ 1 1/2-in. nominal diameter.
 - Chilled water, refrigerant, and brine piping systems:
 - 1 in. insulation for pipes \leq 1 1/2-in. nominal diameter,

- 1 1/2 in. insulation for pipes >1 1/2-in. nominal diameter.
- Steam piping:
- 1 1/2 in. insulation for pipes ≤1 1/2-in. nominal diameter,
3 in. insulation for pipes >1 1/2-in. nominal diameter.
- Exception: Pipe insulation is not required for factory-installed piping within HVAC equipment.
 - Exception: Pipe insulation is not required for piping that conveys fluids having a design operating temperature range between 55°F and 105°F.
 - Exception: Pipe insulation is not required for piping that conveys fluids that have not been heated or cooled through the use of fossil fuels or electric power.
 - Exception: Pipe insulation is not required for runout piping not exceeding 4 ft in length and 1 in. in diameter between the control valve and HVAC coil.
11. Operation and maintenance documentation must be provided to the owner that includes at least the following information:
 - a) equipment capacity (input and output) and required maintenance actions
 - b) equipment operation and maintenance manuals
 - c) HVAC system control maintenance and calibration information, including wiring diagrams, schematics, and control sequence descriptions; desired or field-determined set points must be permanently recorded on control drawings, at control devices, or, for digital control systems, in programming comments
 - d) complete narrative of how each system is intended to operate.
 12. Thermostats controlling both heating and cooling must be capable of maintaining a 5°F deadband (a range of temperature where no heating or cooling is provided).
 - Exception: Deadband capability is not required if the thermostat does not have automatic changeover capability between heating and cooling.
 - Exception: Special occupancy or special applications where wide temperature ranges are not acceptable and are approved by the authority having jurisdiction.
 13. Balancing devices provided in accordance with IMC (2006) 603.17.
 14. Outdoor air supply and exhaust systems must have motorized dampers that automatically shut when the systems or spaces served are not in use. Dampers must be capable of automatically shutting off during preoccupancy building warm-up, cool-down, and setback, except when ventilation reduces energy costs (e.g., night purge) or when ventilation must be supplied to meet code requirements. Both outdoor air supply and exhaust air dampers must have a maximum leakage rate of 3 cfm/ft² at 1.0 in w.g. when tested in accordance with AMCA Standard 500.
 - Exception: Gravity (non-motorized) dampers are acceptable in buildings less than three stories in height.
 - Exception: Systems with a design outside air intake or exhaust capacity of 300 cfm (140 L/s) or less that are equipped with motor operated dampers that open and close when the unit is energized and de-energized, respectively.
 15. Individual fan systems with a design supply air capacity of 5000 cfm or greater and minimum outside air supply of 70% or greater of the supply air capacity must have an energy recovery system with at least a 50% effectiveness. If an air economizer is also required, heat recovery must be bypassed or controlled to permit air economizer operation.
 - Exception: Systems serving spaces that are not cooled and heated to <60°F.
 - Exception: Commercial kitchen hoods (grease) classified as Type 1 by NFPA 96.
 - Exception: Systems exhausting toxic, flammable, paint, or corrosive fumes or dust.
 - Exception: Where the largest exhaust source is less than 75% of the design outdoor airflow.
 - Exception: Systems requiring dehumidification that employ energy recovery in series with the cooling coil.