


ELECTRICAL LEGEND		
SYM.	DESCRIPTION	NOTE NO.
⊕	STANDARD 120V DUPLEX RECEPT. @ 18" AFF. (UNLESS NOTED)	
⊕D	DEDICATED RECEPTACLE SEE PNL SCHEDULE FOR CIRCUIT SIZE	
⊕GFI	GFI 120V DUPLEX RECEPTACLE @ 18" A.F.F. (UNLESS NOTED)	
⊕WP	WEATHER PROOF 120V DUPLEX RECEPT. @ 30" A.F.F. (UNLESS NOTED)	
⊕C	STANDARD 120V DUPLEX RECEPT. @ COUNTER HEIGHT	
⊏	FUSED POWER DISCONNECT	
▶	DUAL CAT.5 JACK WITH FACEPLATE NETWORKING CONNECTION	
⊕WH	ELEC WATER HTR INSTALLED ON DECK ABOVE LOCATION INDICATED	
⊕AC	AIR CONDITIONING CONDENSOR UNIT SEE MECH SHEETS FOR UNIT DETAILS	
⊕E	CEILING MTD MECHANICAL EXHAUST FAN	
⊕E	ELECTRIC PANEL SEE SHEET E-3 FOR PANEL SCHEDULE	
⊕SD	SMOKE DETECTOR, U.L. LISTED, PHOTOELECTRIC, DIGITAL, INTELLIGENT	1

EQUIPMENT NOTES:
 1. SMOKE AND HEAT DETECTORS SHALL NOT BE INSTALLED CLOSER THAN 1'-0" TO A LIGHT FIXTURE OR WITHIN 3'-0" FROM A HVAC AHU/RTU AIR SUPPLY DIFFUSER.

POWER PLAN
 SCALE: 1/4"=1'



DAMMON ENGINEERING, INC.

CHIEF ENGINEER
 EMMETT DAMMON, P.E.

CHIEF ARCHITECT
 ROBERT WILTSE

1095 FLORIDA AVENUE
 SLIDELL, LA. 70458
 OFFICE: 985-649-5832
 FAX: 985-641-5950

WEBSITE:
 WWW.DAMMONENGINEERING.COM

EMAIL:
 DAMMONENG@BELLSOUTH.NET

- ARCHITECTURE
- ENGINEERING
- STUDIES
- PLANNING
- INVESTIGATION
- EXPERT WITNESS

NEW LIVING FACILITY

STARC WEST
 1705 VIOLA ST
 MANDEVILLE, LA

POWER PLAN

REV:

SCALE: AS NOTED

JOB#: 2081

DATE: 11-4-10

SHEET 14

E-1

OF 17