



Envelope Compliance Certificate

90.1 (2007) Standard

Section 1: Project Information

Project Type: **Alteration**
Project Title : Trakside Tavern

Construction Site:
64441 Highway 3081
Pearl River, LA 70452

Owner/Agent:
Kash Wilson
Pearl River, LA 70452

Designer/Contractor:
Chuck Dammon
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: General Information

Building Location (for weather data): **Pearl River, Louisiana**
Climate Zone: **2a**
Building Type for Envelope Requirements: **Non-Residential**

Activity Type(s) **Floor Area**
bar (Common Space Types:Lounge/Recreation) 1504

Section 3: Requirements Checklist

Envelope PASSES

Climate-Specific Requirements:

Post-Alteration Assembly	R-Value		Proposed		Max. Allowed	
	Cavity	Cont.	U-Factor	SHGC	U-Factor	SHGC
Interior Wall 1: Wood-Framed, 16" o.c. Exemption: Cavity filled with minimum R-3/inch insulation	---	---	---	---	---	---

Insulation:

- 1. Open-blown or poured loose-fill insulation has not been used in attic roof spaces with ceiling slope greater than 3 in 12.
- 2. Wherever vents occur, they are baffled to deflect incoming air above the insulation.
- 3. Recessed lights, equipment and ducts are not affecting insulation thickness.
- 4. No roof insulation is installed on a suspended ceiling with removable ceiling panels.
- 5. All exterior insulation is covered with protective material.
- 6. Cargo and loading dock doors are equipped with weather seals.

Fenestration and Doors:

- 7. Windows and skylights are labeled and certified by the manufacturer for U-factor and SHGC.
- 8. Fixed windows and skylights unlabeled by the manufacturer have been labeled using the default U-factor and SHGC.
- 9. Other unlabeled vertical fenestration, operable and fixed, that are unlabeled by the manufacturer have been site labeled using the default U-factor and SHGC. No credit has been given for metal frames with thermal breaks, low-emissivity coatings, gas fillings, or insulating spacers.

Air Leakage and Component Certification:

- 10. All joints and penetrations are caulked, gasketed, weather-stripped, or otherwise sealed.
- 11. Windows, doors, and skylights certified as meeting leakage requirements.

447029

REVIEWED FOR
STATE FIRE MARSHAL
AS PER REVIEW LETTER
BY: ERIC L. PARNELL, ARCHITECT



COMcheck Software Version 3.9.0

Interior Lighting and Power Compliance Certificate

90.1 (2007) Standard

Section 1: Project Information

Project Type: **Alteration**
Project Title : Trackside Tavern

Construction Site:
64441 Highway 3081
Pearl River, LA 70452

Owner/Agent:
Kash Wilson
Pearl River, LA 70452

Designer/Contractor:
Chuck Dammon
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: Interior Lighting and Power Calculation

A Area Category	B Floor Area (ft ²)	C Allowed Watts / ft ²	D Allowed Watts (B x C)
bar (Common Space Types:Lounge/Recreation): Exempt			
Total Allowed Watts =			N/A

Area Category Exemption Qualifications

Activity Area	Total Wattage		Total Pre-Alt. Fixtures	# Fixtures Repl./Added
	Pre-Alt.	Post-Alt.		
bar (Common Space Types:Lounge/Recreation 1504 sq.ft.): Exemption: Less than 50% fixture replacement.	25	25	50	19

Section 3: Interior Lighting Fixture Schedule

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
bar (Common Space Types:Lounge/Recreation 1504 sq.ft.): Exempt Compact Fluorescent 1: Twin Tube 18W / Magnetic	2	11	20	220
Total Proposed Watts =				N/A

Section 4: Requirements Checklist

Lighting Wattage:

1. Total proposed watts must be less than or equal to total allowed watts.

Allowed Watts	Proposed Watts	Complies
N/A	N/A	Passes

2. Exit signs 5 Watts or less per sign.

Controls, Switching, and Wiring:

3. Independent manual or occupancy sensing controls for each space (remote switch with indicator allowed for safety or security).
 4. Occupant sensing control in class rooms, conference/meeting rooms, and employee lunch and break rooms.

Exceptions:



COMcheck Software Version 3.9.0

Exterior Lighting Compliance Certificate

90.1 (2007) Standard

Section 1: Project Information

Project Type: **Alteration**

Project Title : Trackside Tavern

Construction Site:
64441 Highway 3081
Pearl River, LA 70452

Owner/Agent:
Kash Wilson
Pearl River, LA 70452

Designer/Contractor:
Chuck Dammon
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: Exterior Lighting Area/Surface Power Calculation

A Exterior Area/Surface	B Quantity	C Allowed Watts / Unit	D Tradable Wattage	E Allowed Watts (B x C)	F Proposed Watts
Main entry/exit	2 ft of door width	30	Yes	60	65
Illuminated area of wall or surface	1875 ft2	0.2	No	375	140
Total Tradable Watts* =				60	65
Total Allowed Watts =				435	
Total Allowed Supplemental Watts** =				22	

* Wattage tradeoffs are only allowed between tradable areas/surfaces.

** A supplemental allowance equal to 5% of total allowed wattage may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Section 3: Exterior Lighting Fixture Schedule

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Main entry/exit (2 ft of door width): Tradable Wattage				
Incandescent 1: Incandescent 65W	1	1	65	65
Illuminated area of wall or surface (1875 ft2): Non-tradable Wattage				
HID 1: Metal Halide 70W / Standard	1	2	70	140
Total Tradable Proposed Watts =				65

Section 4: Requirements Checklist

Lighting Wattage:

1. Within each non-tradable area/surface, total proposed watts must be less than or equal to total allowed watts. Across all tradable areas/surfaces, total proposed watts must be less than or equal to total allowed watts.

Compliance: Passes using supplemental allowance watts.

Controls, Switching, and Wiring:

2. All exemption claims are associated with fixtures that have a control device independent of the control of the nonexempt lighting.
3. All lighting fixtures are controlled by a photosensor or astronomical time switch that is capable of automatically turning off the fixture when sufficient daylight is available or the lighting is not required.



Mechanical Compliance Certificate

90.1 (2007) Standard

Section 1: Project Information

Project Type: **Alteration**

Project Title : Trackside Tavern

Construction Site:
64441 Highway 3081
Pearl River, LA 70452

Owner/Agent:
Kash Wilson
Pearl River, LA 70452

Designer/Contractor:
Chuck Dammon
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458
985-649-5832
dammoneng@bellsouth.net

Section 2: General Information

Building Location (for weather data): **Pearl River, Louisiana**
Climate Zone: **2a**

Section 3: Mechanical Systems List

Quantity	System Type & Description
2	HVAC System 1: Cooling: 2 each - Split System, Capacity = 2 kBtu/h, Air-Cooled Condenser Exemption: Extensive ancillary requirements.

Section 4: Requirements Checklist

No Generic Requirements apply since there are no HVAC systems that require code compliance.

Section 5: Compliance Statement

Compliance Statement: The proposed mechanical alteration project represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed mechanical alteration project has been designed to meet the 90.1 (2007) Standard, Chapter 8, requirements in COMcheck Version 3.9.0 and to comply with the mandatory requirements in the Requirements Checklist.





Name - Title _____ Signature _____ Date _____

Section 6: Post Construction Compliance Statement

- HVAC record drawings of the actual installation and performance data for each equipment provided to the owner within 90 days after system acceptance.
- HVAC O&M documents for all mechanical equipment and system provided to the owner within 90 days after system acceptance.
- Written HVAC balancing report provided to the owner.

The above post construction requirements have been completed.

Principal Mechanical Designer-Name _____ Signature _____ Date _____



COMcheck Software Version 3.9.0

Mechanical Requirements Description

90.1 (2007) Standard

No Generic Requirements apply since there are no HVAC systems that require code compliance.