



# DAMMON

ENGINEERING, INC.

554 Old Spanish Trail  
Slidell, LA 70458  
Phone: 985-649-5832

dammonengineering.com  
info@dammonengineering.com

---

May 4, 2018

City Of Slidell  
Building Safety and Permits  
Slidell, La. 70458

Attn: Greg Gordan

Ref: Pinewood Wedding Venue

Per our inspection at the above referenced site please accept this letter of approval.

- 1) Bottom plate to foundation with 5/8" x 10" anchor bolts @ ???
- 2) All steel building columns anchored with 3/4" x 18" anchor bolts.
- 3) 24 inch Simpson strong tie CS 16 straps every other stud on gable walls between top and bottom floors.
- 4) 10 inch joist hangers nailed to band and used rafter ties nailed to every rafter to top plate.

Sincerely,

Chuck Dammon, VP

Accepted: \_\_\_\_\_ Date: \_\_\_\_\_