



NOTES

- ① PROVIDE RECEPTACLE FOR LIGHTING EQUIPMENT.
- ② 60 CONDUCTORS WIRE PER TABLE.
- ③ 12 CONDUCTORS WIRE PER TABLE.
- ④ 24 CONDUCTORS WIRE PER TABLE.
- ⑤ 36 CONDUCTORS WIRE PER TABLE.
- ⑥ PROVIDE DEDICATED 30A, 220V, NEMA L6-30R RECEPTACLE FOR FOLLOW SPOT.
- ⑦ INDEX STRIP LIGHT, PROVIDED AND INSTALLED BY STAGE RIGGING CONTRACTOR. PROVIDE AND INSTALL 1000W WALL BOX DIMMER MOUNTED AT 4'-0" A.F.F. CONNECTED TO A JUNCTION BOX AT +10'-0" A.F.F. THE INDEX STRIP LIGHT WILL INCLUDE A FLEXIBLE SHIP FOR CONNECTION TO THE JUNCTION BOX.
- ⑧ SEE SINGLE LINE DIAGRAM FOR FEEDER REQUIREMENTS.

CIRCUIT WIRING TABLE

DISTANCE	20A	50A
0' - 145'	#10	#6
146' - 225'	#8	#4
226' - 350'	#6	#2

NOTICE

- (APPLIES TO DIMMER & RELAY CONTROLLER CIRCUITS)
1. EACH 120V CIRCUIT SHALL BE 2 CONDUCTORS, SEPARATE NEUTRALS REQUIRED FOR ALL 120V CIRCUITS.
 2. RACEWAY FILL SHALL BE PER NEC CHAPTER 9.
 3. SEE DIMMER SCHEDULE SHEET E8.01 FOR RECEPTACLE TYPES.
 4. PROVIDE DERATING OF CONDUCTORS PER NEC TABLE 310.15(B)(2)(a).
 5. REFER TO SCHULER SHOOK DRAWINGS FOR LIGHTING SYSTEM CONTROL REQUIREMENTS. PROVIDE ALL RACEWAYS, BOXES, OUTLETS, CONNECTORS, EQUIPMENT, ETC. PER THEATRICAL LIGHTING CONSULTANT DRAWINGS.

THE SAENGER THEATRE RENEWAL PROJECT

142 North Rampart Street
New Orleans, LA

Client
Saenger Theatre Redevelopment Company
200 West Loop South, Suite 1040
Houston TX 77027

Architect
MARTINEZ+JOHNSON ARCHITECTURE
1412 Eye St., NW
Washington, DC 20005
202.333.4480

Structural Engineer
Shawn J. Franke, P.E.
549 Hermit Road, San Antonio TX 78232
210.979.7900

Theatre Consultant
Schuler Shook
123 Third Street North #210
Minneapolis, MN 55401
612.333.5659

Acoustical Engineer
Akustiks
93 North Main Street South
Norwalk, CT 06584
202.299.1904

MEP Engineer
JBA Consulting Engineers, Inc.
3525 N. Causeway Blvd., Suite 500
Metairie, LA 70002
504.830.0139

Civil Engineer
Linfield, Hunter, & Junius, Inc.
3608 18th Street Suite 200
Metairie, LA 70002
504.833.5300

Architectural Historian
EHT Traceres, Inc.
1121 Fifth Street NW
Washington, DC 20001
202.393.1199

THESE DRAWINGS, SPECIFICATIONS, AND OTHER DOCUMENTS, COLLECTIVELY, THE "DOCUMENTS", INCLUDING WITHOUT LIMITATION ELECTRONIC VERSIONS THEREOF AND THE IDEAS, DESIGNS, AND ARRANGEMENTS REPRESENTED THEREBY, ARE AND SHALL REMAIN THE PROPERTY OF MARTINEZ+JOHNSON ARCHITECTURE, P.C. AS DEFINED BY APPLICABLE CONTRACTUAL AGREEMENTS (THE "AGREEMENTS") AND AS PROTECTED BY THE COPYRIGHT STATUTES OF THE UNITED STATES. USE OF THE DOCUMENTS SHALL BE STRICTLY LIMITED TO THE PROJECT FOR WHICH THEY WERE PREPARED AND DEVELOPED (THE "PROJECT") FOR THE TERMS OF THE AGREEMENTS. NO PART OF THE DOCUMENTS SHALL BE COPIED, DISCLOSED TO OTHERS, OR USED IN CONNECTION WITH ANY OTHER WORK OR PROJECT, OR BY ANY OTHER PERSONS FOR ANY PURPOSES, OTHER THAN THE COMPLETION OF THE PROJECT, WITHOUT THE SPECIFIC WRITTEN AUTHORIZATION OF MARTINEZ+JOHNSON ARCHITECTURE, P.C. THE COPYING, GAINING, OPENING, OR VIEWING OF ELECTRONIC VERSIONS OF THE DOCUMENTS OR VISUAL CONTACT WITH ANY PRINTED FORM THEREOF SHALL CONSTITUTE CONCLUSIVE EVIDENCE OF ACCEPTANCE OF THESE RESTRICTIONS.

7502

DATE:	No.:	ISSUE:
02.19.10	1	PERMIT SET
04.02.10	2	GMP CONTRACT SET

DATE:	No.:	REVISION:
06.16.10	1	PERMIT REVISION
11.11.10		CONTRACT SET

SHEET TITLE:
THEATRE -
UPPER BALCONY /
FOLLOW SPOT ROOM
LEVEL - THEATRICAL
LIGHTING

ETL-1.09

THEATRE - FOLLOW SPOT ROOM - THEATRICAL LIGHTING PLAN

THEATRE - UPPER BALCONY LEVEL - THEATRICAL LIGHTING PLAN

1/8" = 1'-0"

1

ISSUED FOR PERMIT