

## Dammon Engineering

---

**From:** William.Himber@cleco.com  
**Sent:** Thursday, August 12, 2010 8:40 AM  
**To:** Dammon Engineering  
**Subject:** 520 old Spanish trail

Kurt, the disconnect and metering equipment located at 520 Old Spanish Trail, is at the proper height for CLECO to read meter and maintain our equipment. It is also at the proper height for CLECO to disconnect service in the event of an emergency.

William Himber  
Project Coordinator  
CLECO POWER LLC  
985-661-3247

8/12/2010