

SECTION 331113
POTABLE WATER SUPPLY WELLS

PART 1 - GENERAL

1.1 SUMMARY

- A. This Section includes the following:
 - 1. Potable Water Supply Wells.

1.2 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Contractor shall hire a licensed company to design and install the Potable Water Supply Well. Minimum Performance Capacity: 5 gallons per minute.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type and size of pump indicated.
- B. Shop Drawings: Show layout and connections for well pumps.
 - 1. Include wiring diagrams.

1.4 INFORMATIONAL SUBMITTALS

- A. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and maintenance data.
- B. Demonstration and Training. Provide site personnel training on operation of the water well.

1.6 QUALITY ASSURANCE

- A. Potable Water Supply Wells Qualifications: An experienced Potable Water Supply Wells licensed in the jurisdiction where Project is located.

ST. TAMMANY FIRE PROTECTION DISTRICT NO. 1
FIRE STATION #19
57047 ALLEN ROAD
SLIDELL LA 70461

- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with the Louisiana Public Health - Sanitary Code Part XII for Water Wells and St Tammany Parish Health Department.

PART 2 - PRODUCTS

Not Used

PART 3 - EXECUTION

Not Used

END OF SECTION 331113