

Permit		Permittee: DEPT OF PUBLIC SAFETY		Facility: DEPT OF PUBLIC SAFETY - STATE POLICE TROOP L	
Permit #: LAG481115	Major: No	Permittee Address: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471	Facility Location: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471		
Permitted Feature: 001 External Outfall	Discharge: 001-S Outfall 001				

Report Dates & Status	Monitoring Period: From 07/01/22 to 12/31/22	DMR Due Date: 01/28/23	Status: NetDMR Validated
----------------------------------	---	-------------------------------	---------------------------------

Considerations for Form Completion
TSS limit for oxidation ponds shall be 90 mg/L Monthly Average and 135 mg/L Daily Maximum Fecal Coliform limit for oyster propagation area shall be 14 #/100ml Monthly Average and 43 #/100ml Daily Maximum

Principal Executive Officer		Title:	Telephone:
First Name:			
Last Name:			

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Ty			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.7			=	7.7	12 - SU	0	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.						>=	6.0 INST MIN			<=	9.0 INST MAX	12 - SU		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	11.0			=	11.0	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.						<=	30.0 MO AVG			<=	45.0 DAILY MX	19 - mg/L		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	63.4			=	63.4	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
X 00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample						=	75.6			=	75.6	19 - mg/L	2	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.						<=	5.0 MO AVG			<=	10.0 DAILY MX	19 - mg/L		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	6.4			=	6.4	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.											Req Mon DAILY MX	19 - mg/L		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	200.0	=	200.0	07 - gal/d								0	01/6M - Once Every 6 Months	ES - ESTII
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	07 - gal/d									01/6M - Once Every 6 Months	ES - ESTII
					Value NODI															
X 74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						>	2419.6			>	2419.6	13 - #/100mL	2	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.						<=	200.0 MOAV GEO			<=	400.0 DAILY MX	13 - #/100mL		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															
X 80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	27.0			=	27.0	19 - mg/L	1	01/6M - Once Every 6 Months	GR - GRAE
					Permit Req.						<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L		01/6M - Once Every 6 Months	GR - GRAE
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
74055	Coliform, fecal general	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments
The CBOD was retested on 11-17-22 and passed at <3. Please see attached non-compliance form.

Name	Type	Size
TroopLOutfall0012B2022.pdf	pdf	161454.0

Report Last Saved By
DEPT OF PUBLIC SAFETY

User: JDU PONT1980
Name: Jennifer Dupont
E-Mail: jdupont@eeusa.com
Date/Time: 2023-01-24 09:55 (Time Zone: -06:00)

Report Last Signed By

User: LSP_TROOPL
Name: Louis Calato
E-Mail: louis.calato@la.gov
Date/Time: 2023-01-26 15:38 (Time Zone: -06:00)

Submission Receipt

Submission Date: 01-26-2023

Submitter Name: Louis Calato

Submitter Telephone: (985) 893-6250

Attachment 1



Non-Compliance Report Form

Facility Name: Department of Public Safety State Police Troop L

Facility Address: (Semi-Annual) 2600 N. Causeway Blvd., Mandeville, LA 70471

Person Reporting: Lt. Louis Calato **Title:** Lieutenant

Phone Number: 985-893-6239 **Parish:** St. Tammany

LPDES Number: LAG481115 **AI#:** 22734

Receiving Waters: From Bayou Tete L' Ours via local Drainage in (subsegment 040808) of the Lake Pontchartrain Basin.

(Refer to Subject Line on Permit Cover Letter)

Date of Non-Compliance	Parameter/Description (e.g. TSS, Overflow)	Outfall No./Location (e.g. 001, 123 Main St.)	Permit Limit	Reported Value
09-22-22	CBOD ₅	Outfall 001	10	27
09-22-22	Fecal Coliform	Outfall 001	200	>2,419.6
09-22-22	Ammonia Nitrogen	Outfall 001	5	73.8
11-17-22	Fecal Coliform	Outfall 001	200	>2,419.6
11-17-22	Ammonia Nitrogen	Outfall 001	5	75.6

Cause of Violation(s): The tank is not getting enough aeration.

Corrective Action/Preventative Measures/Remediation: Environmental services are being contacted to access how to correct this problem.

Please submit as a PDF attachment in NetDMR or mail non-compliance reports to the following address:

**Office of Environmental Compliance
Attn: Permit Compliance Unit
P.O. Box 4312
Baton Rouge, LA 70821-4312**