

Permit

Permit #: LAG481115	Permittee: DEPT OF PUBLIC SAFETY	Facility: DEPT OF PUBLIC SAFETY - STATE POLICE TROOP L
Major: No	Permittee Address: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471	Facility Location: 2600 N CAUSEWAY BLVD MANDEVILLE, LA 70471
Permitted Feature: 002 External Outfall	Discharge: 002-Q Exterior Vehicle & Equip. Wash, Equip. Repair Area, Shop Floor, & Dock Washdown, & Utility WashWater	

Report Dates & Status

Monitoring Period: From 01/01/22 to 03/31/22	DMR Due Date: 04/28/22	Status: NetDMR Validated
---	-------------------------------	---------------------------------

Considerations for Form Completion

COD limit for washwater commingled with stormwater shall be 125mg/L Daily Maximum

Principal Executive Officer

First Name:	Title:	Telephone:
Last Name:		

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Ty		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00340	Oxygen demand, chem. [high level] [COD]	1 - Effluent Gross	0	--	Sample								<	12.0	<	12.0	19 - mg/L	0	01/90 - Quarterly	GR - GRAE
					Permit Req.								<=	200.0 MO AVG	<=	300.0 DAILY MX	19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.7			=	7.7	12 - SU	0	01/90 - Quarterly	GR - GRAE	
					Permit Req.					>=	6.0 INST MIN			<=	9.0 INST MAX	12 - SU				
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample									<	5.0	19 - mg/L	0	01/90 - Quarterly	GR - GRAE	
					Permit Req.								<=	45.0 DAILY MX	19 - mg/L					
					Value NODI															
00556	Oil & Grease	1 - Effluent Gross	0	--	Sample									=	8.8	19 - mg/L	0	01/6M - Once Every 6 Months	GR - GRAE	
					Permit Req.								<=	15.0 DAILY MX	19 - mg/L					
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	160.0	=	160.0	07 - gal/d								0	01/90 - Quarterly	ES - ESTII
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	07 - gal/d										
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments
No attachments.

Report Last Saved By
DEPT OF PUBLIC SAFETY

User: JDUPONT1980
Name: Jennifer Dupont
E-Mail: jdupont@eeusa.com
Date/Time: 2022-04-08 09:26 (Time Zone: -05:00)

Report Last Signed By

User: LSP_TROOPL
Name: Louis Calato
E-Mail: louis.calato@la.gov
Date/Time: 2022-04-11 10:49 (Time Zone: -05:00)

Submission Receipt

Submission Date: 04-11-2022

Submitter Name: Louis Calato

Submitter Telephone: (985) 893-6250