

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

**INFORMATION REQUEST
NOT - FOR - PERMITTING**

ROBERT WILTSE
DAMMON ENGINEERING INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0381505
CSP AREA UPGRADE
1001 GAUSE BLVD
SLIDELL, LA 70458-0000

NFPA 101, 2006

HOSPITAL

Dear Applicant:

Additional information is required to perform a proper review. The project referenced above is being held pending submission of the following information:

1. **RS 40:1574 and/or RS 40:1730.39.A Additional drawings and/or specifications are required:**
 - a) **101:18.2.5.6.3.4 (A) (2) Travel distance within a non-sleeping suite to an exit access door from the suiteshall not exceed 50' where the suite is arranged with two intervening rooms. (TRAVEL DISTANCE EXCEEDS 50' WITHIN THE SUITE FROM ROOM 109 TO A CORRIDOR DOOR FROM THE SUITE. PROVIDE A FLOOR PLAN SHOWING A MAXIMUM OF 50' TRAVEL WITHIN THE SUITE TO A CORRIDOR DOOR)**
 - b) **PROVIDE A BUILDING SECTION INDICATING NUMBER OF FLOORS PENETRATED BY EXHAUST DUCT TO ROOF AND MECHANICAL PLAN SHOWING ROUTING OF THE HOOD EXHAUST DUCT TO THE EXTERIOR OF THE BUILDING.**
2. **NOTE: Please ENCLOSE A COPY OF THIS LETTER WITH FUTURE SUBMITTALS OR OTHER CORRESPONDENCE pertaining to this project.**

Due to the lack of information, the referenced project has NOT been reviewed. Please direct the requested information to my attention. Processing will continue upon receipt of the information requested above. Enclose a copy of this letter with future submittals and/or other correspondence pertaining to this project.

This project will be returned as "NOT IN COMPLIANCE" if the requested information is not received by this office within 21 days of the date of this letter, thereby requiring a RESUBMITTAL of the entire project along with a new completed application and appropriate review fee.

Jun 30, 2010
P0381505 - PAGE 1

CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review has been performed and a formal review letter has been issued by this office.

REVIEWED BY:
GORDON CAMERON
ARCHITECT

CC:
Slidell Memorial Hospital
Healthcare District* 2259254270
State Plumbing Board Of Louisiana*
St Tammany Fire Protection District No 1*
City Of Slidell*