

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

**INFORMATION REQUEST
NOT - FOR - PERMITTING**

ROBERT WILTSE
DAMMON ENGINEERING INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0390487
PATTERSON DENTAL SUPPLY
107 MALLARD STREET
SAINT ROSE, LA 70087

NFPA 101, 2009

BUSINESS

Dear Applicant:

Additional information is required to perform a proper review. The project referenced above is being held pending submission of the following information:

1. **RS 40:1574 Additional drawings and/or specifications are required:**
 - a) Please indicate the previous Occupancy Type of the area to be used for the Patterson Expansion and the Occupancy Type of the adjacent tenant space.
2. **101:7.5.1.3 Two remotely located exits are required from BUSINESS AREA. Minimum distance between them, measured from closest jambs, shall be 1/2 the maximum diagonal length of space or area (1/3 the diagonal is permitted if the building is protected throughout by an approved SUPERVISED sprinkler system per 9.7).**
 - a) **101:7.5.2.1 Exit access shall not be through kitchen, storeroom, workroom or similar space.**
3. **101:38.2.4 and 2.5 Travel to exits shall be by different paths in different directions; a common path of travel for the first 75 feet is permitted. Provide remotely located means of egress.**
4. **101:38.3.2 Separate REPAIR ROOM, NEW REPAIR ROOM & STORAGE ROOM from other parts of the building by 1 hour fire resistive construction with self-closing 45 minute labeled door/frame assembly in accordance with Section 8.7.1 WITHOUT WINDOWS, -OR- provide automatic sprinkler protection in accordance with Section 9.7 and smoke partitions with self-closing doors in accordance with Section 8.4. (Sprinkler piping for isolated hazardous areas connected to domestic water supply shall comply with 101:9.7.1.2).**
5. **NOTE: Please mail all correspondence related with this project to:**

NEW ORLEANS PLAN REVIEW
Office of State Fire Marshal

Dec 13, 2010
P0390487 - PAGE 1

2750 Lake Villa Drive, Suite 301
Metairie, LA 70002

Contact the reviewer at 504.455.7315 (fax: 504.455.7317), if you have any questions regarding this project.

6. **NOTE: Please ENCLOSE A COPY OF THIS LETTER WITH FUTURE SUBMITTALS OR OTHER CORRESPONDENCE pertaining to this project.**

Due to the lack of information, the referenced project has NOT been reviewed. Please direct the requested information to my attention. Processing will continue upon receipt of the information requested above. Enclose a copy of this letter with future submittals and/or other correspondence pertaining to this project.

This project will be returned as "NOT IN COMPLIANCE" if the requested information is not received by this office within 21 days of the date of this letter, thereby requiring a RESUBMITTAL of the entire project along with a new completed application and appropriate review fee.

CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review has been performed and a formal review letter has been issued by this office.

REVIEWED BY:
JULIE LITTLE
ARCHITECT

CC:
Patterson Dental
St Charles Parish Planning Dept
New Orleans District* 5044557313