

# DAMMON ENGINEERING, INC.

dammonengineering.com

*ARCHITECTS*

*ENGINEERS*

*CONSULTING*

*DESIGN*

*STUDIES*

*EXPERT WITNESS*

554 Old Spanish Trail  
Slidell, LA 70458

985-649-5832  
FAX 985-641-5950

April 17, 2012

Zachary R. Smith  
Building Plan Examiner. Plan Review Division  
Department of Safety and Permits  
1300 Perdido Street  
Room 7E06  
New Orleans, LA 70112

RE: Permit # 12COM-OO403 DENTAL OFFICE

Mr. Smith:

Per your request, via email, dated April 17, 2012, please accept this formal response to your comments.

## **Architectural**

- 1) This is classified as a group B for business.
- 2) There are only three dental chairs that will receive gas, see attached, signed, letter.

## **Mechanical**

- 1) We have added the note on sheet M-1 and P-2 for the requirement to meet section 1202.1 and 1202.4 Chapter 12, IBC 2009.
- 2) We have added on sheet P-1 the drains for the AHU, they are also noted on P-2.
- 3) Sheet M-2 already had noted the smoke detector in the detail and the mechanical notes.

Thank you for your help in this matter.

Sincerely,



Robert L. Wiltse, Chief Architect  
Dammon Engineering, Inc.



Attachment: Letter from Bridgett Jones McGeathy & Norman McGeathy III, Owners



**A WORLD OF SMILES LLC  
7240 CROWDER BLVD SUITE 100  
NEW ORLEANS LA 70126**

**MAILING ADDRESS:  
5800 WRIGHT ROAD  
NEW ORLEANS, LA 70128**

**March 12, 2012**

**To whom it may concern:**

**We are writing to inform the Fire Marshall that at our dental office, A World of Smiles located at 7240 Crowder Blvd. in New Orleans, there will NOT be more than two sedated patients at the same time. Thank you.**

**Regards,**

**Dr. Brigitte Jones**

**Dr. Norman McGeathy III**