



St. Tammany Fire Protection District #1 - Fire Prevention Bureau

1358 Corporate Square Slidell La.
70458
PO Box 1149

Phone: 985-646-4387

Fax: 985-646-4864

This inspection is intended for your safety and the safety of the citizens of Louisiana. Your cooperation is greatly appreciated.

Occupancy: Cardiac Rehab
Address: 1001 Gause Blvd
Date of Inspection: 8/7/2014 9:00:00 AM

Severity	Location	Code	Reason
Deficient	Throughout	NFPA (General Lookup)	NFPA 10-7.3.1.1 All Portable Fire Extinguishers. 7.3.1.1.1 Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection or electronic notification. Note: have fire extinguishers inspected and green tagged by a La licensed fire extinguisher company.
		Completion Certificate Required	Chuck Dammon will forward certificate of completion to our office. PO# 440251

Inspection Result: Deficiencies noted
Re-Inspection Date: 9/7/2014 9:29:00 AM
Completed By: Gaubert, Jason

Report Received By:
Tom Alford
Report Created By:
Gaubert, Jason

R.S. 40:1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, of Title 40 of the Louisiana Revised Statutes of 1950, R.S. 50:1569 expected, shall be fined not more than five hundred dollars or imprisoned, for not more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished at the discretion of the court.