ELECTRICAL EQUIPMENT SCHEDULE

EQUIPMENT NUMBER	DESCRIPTION	MODEL	QTY	VOLTAGE	ELECTRICAL					
					PHASE	AMPERAGE	NEMA CONFIGURATION	MOUNTING	NOTES	TERMINATION
E-29B	SUGAR SHOT SUGAR DISPENSER	INTERNATIONAL DELIGHT -215	1	120 V	1	3.2 A	5-20	FLUSH		RECEPTACLE
E-29C	SURE SHOT CREAMER DISPENSER	INTERNATIONAL DELIGHT -215	1	120 V	1	3.2 A	5-20	FLUSH		RECEPTACLE
E-35D	POS SYSTEM (2 STATIONS)	CWS	1	120 V	1	3.0 A	5-20	SURFACE		RECEPTACLE
E-35E	CASH REGISTER DRAWER	CWS	1	120 V	1	3.0 A	5-20	SURFACE		RECEPTACLE
F-1	GAS & DIESEL SYSTEM POWER CENTER	-	1	208 V	3	150.0 A	N/A	SURFACE		JUNCTION BOX
F-7	FUEL MONITORING PANEL		1	120 V	1	1.0 A	5-20	RECESSED		RECEPTACLE
F-23	ABSORBENT ROLL		1	120 V	1	1.0 A	5-20	RECESSED		RECEPTACLE
F-24	ABSORBENT BOOM		1	120 V	1	1.0 A	5-20	RECESSED		RECEPTACLE
F-27	CAT SCALE CONSOLE	CAT SCALES	1	120 V	1	3.5 A	5-20	FLUSH		RECEPTACLE
F-32	DIESEL FUEL CONSOLE	TRENDAR SYSTEMS	1	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
F-32A	FUEL CONSOLE PRINTERS	-	1	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
F-33	COMPCHECK PRINTER	-	1	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
F-34	FUEL MAN SYSTEM	-	1	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
F-35	FAX MACHINE	-	1	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
F-37	FUEL CONTROLLER	-	1	120 V	1	4.0 A	5-20	FLUSH		RECEPTACLE
K-13A	POST MIX AND ICE	IDC-PRO WITH DRIP TRAY (621058656)	2	120 V	1	8.5 A	5-20	FLUSH		RECEPTACLE
K-20	MICROWAVE	PANASONIC - NE-1054F	2	120 V	1	13.4 A	5-15	SURFACE		RECEPTACLE
K-21	WARMING DRAWER	VULCAN - VW1S	2	120 V	1	4.0 A	5-15	SURFACE		RECEPTACLE
K-22	COFFEE BREWER	WILBUR CURTIS - G4GEMT10A1000	2	208 V	2	23.0 A	14-30	FLUSH	E.C. SHALL SUPPLY CORD AND PLUG	RECEPTACLE
K-22A	BEAN TO CUP	SCHAERER COFFEE ART C HC TOUCH	2	208 V	1	16.0 A	L6-20	FLUSH		RECEPTACLE
K-23	COFFEE CREAMER DISPENSER - 2 DISPENSING STATIONS	CREAMISER - MODEL - 210	3	120 V	1	3.2 A	5-20	FLUSH		RECEPTACLE
K-25	HOT DOG GRILL	RUFF RIDER - RR48X	3	120 V	1	11.0 A	5-20	SURFACE		RECEPTACLE
K-27	UNDERCOUNTER FREEZER	TRUE FOOD - TUC-27F-LP-HC	1	120 V	1	5.0 A	5-15	SURFACE		RECEPTACLE
K-29	FOOD PREP TABLE	TRUE FOOD SERVICE EQUIPMENT INC - TSSU-60-08	1	120 V	1	7.8 A	5-15	SURFACE		RECEPTACLE
K-33	PUSH BUTTON ICE MAKER DISPENSER	CORNELIUS - IMD 300-15ASPB	1	120 V	1	15.0 A	5-20	SURFACE		RECEPTACLE
K-34	NITROPRO MINI	CORNELIUS - 621058753CNB	1	120 V	1	5.0 A	5-20	SURFACE		RECEPTACLE
K-56	FOOD PREP TABLE W/ RAISED CONDIMENT RAIL	8260N	2	120 V	1	6.0 A	5-15	FLUSH		RECEPTACLE
K-76	CHILI/CHEESE DISPENSER	GEHL'S DUAL DISPENSER	1	120 V	1	1.7 A	5-20	SURFACE		RECEPTACLE
K-84	HOT FOOD MERCHANDISER	VENDO SADEN - COMBO SERVE (HFDC) 35.3"X19.7" HFD00005	2	120 V	1	9.2 A	5-20	SURFACE		RECEPTACLE
K-85	HEATED SHELF MERCHANDISER	(HFDM) 24.9"X19.7" HFDMXXXXX	1	120 V	1	9.2 A	5-20	SURFACE		RECEPTACLE
K-93	POST MIX ICE MAKER	HOSHIZAKI F-2001MRJ-C	2	208 V	1	18.4 A	L14-20	FLUSH		RECEPTACLE
K-93A	CONDENSER (ON ROOF)		1	120 V	1	1.0 A	5-20	RECESSED		RECEPTACLE
M-1A	COMMERCIAL FRONT LOAD WASHER	SPEED QUEEN - QUANTUM - SFNNCASP115TW01	1	120 V	1	9.8 A	5-20	FLUSH		RECEPTACLE
M-1B	COMMERCIAL FRONT LOAD DRYER	SPEED QUEEN - QUANTUM - SDENCAGS173TW01	1	120 V	1	30.0 A	14-30	FLUSH		RECEPTACLE
M-1C	COMMERCIAL STACK WASHER/DRYER	SPEED QUEEN - QUANTUM - STEBCASP173TW01	2	120 V	1	30.0 A	5-20	FLUSH		RECEPTACLE
M-2A	WASHER FULL SIZE	ALLIANCE - UCN030HNF	1	208 V	3	79.0 A	N/A	SURFACE		NON-FUSED DISCONNECT
M-2B	DRYER FULL SIZE	ALLIANCE - UTO55L UTO55N	1	208 V	3	79.0 A	N/A	FLUSH		NON-FUSED DISCONNECT
M-5C	CASH RECYCLER	GLORY - REG-300 ICR	1	120 V	1	5.8 A	5-20	FLUSH		RECEPTACLE
M-5D	COIN RECYCLER	GLORY - SDRC-100 CRs	1	120 V	1	3.0 A	5-20	FLUSH		RECEPTACLE
M-14	ATM MONEY MACHINE	BY VENDOR	2	120 V	1	3.0 A	N/A	FLUSH		JUNCTION BOX
M-15	COIN CLOUD MACHINE	BY VENDOR	1	120 V	1	3.0 A	N/A	FLUSH		JUNCTION BOX
M-16	TRANSFLO		1	120 V	1	3.0 A	5-20	RECESSED		RECEPTACLE
M-25	FLY TRAP	GILBERT 2156T (BLACK)	4	120 V	1	3.0 A	5-20	FLUSH		RECEPTACLE
M-29	TRANSFLO KIOSK	TRANSCORE	1	120 V	1	3.0 A	5-20	FLUSH		RECEPTACLE
R-3	PAPER TOWEL DISPENSER	SAN JAMAR OCEANS - TEAR-N-DRY - T1390	10	120 V	1	1.5 A	5-20	RECESSED		RECEPTACLE
R-10	HAND DRYER	EXCEL "XLERATOR" XL-SBV	11	120 V	1	12.2 A	N/A	RECESSED		JUNCTION BOX
S-8	CASH REGISTER	CWS	4	120 V	1	3.0 A	5-20	SURFACE		RECEPTACLE
S-10	DIGITAL DISPLAY		11	120 V		3.0 A	5-20	RECESSED		RECEPTACLE
S-16A	OUTDOOR ICE MERCHANDISER	LEER L462LASX	2	120 V	1	5.0 A	5-20	FLUSH		RECEPTACLE
S-17D	12 HEAD DRINK DISPENSER W/ OVERHEAD ICE MAKER ABOVE	ED 300/ KM1601MRJ3	1	120 V	1	5.3 A	5-20	FLUSH		RECEPTACLE
S-21G	PRINTER	-	2	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
S-21L	CASH BOX	-	2	120 V	1	1.0 A	5-20	FLUSH		RECEPTACLE
S-21M	POS SYSTEM (2 STATIONS)	CWS	2	120 V	1	3.0 A	5-20	SURFACE		RECEPTACLE
S-21N	CASH DRAWER	CWS	2	120 V	1	3.0 A	5-20	SURFACE		RECEPTACLE
S-25	ICE CREAM MERCHANDISER	EXCELLENCE INDUSTRIES - GDF-22	1	120 V	1	4.6 A	5-20	FLUSH		RECEPTACLE
S-31	CIGARETTE PRICER		1	120 V	1	1.0 A	5-20	RECESSED		RECEPTACLE
S-38	LOTTO MACHINE		2	120 V	1		5-20			RECEPTACLE
S-52	SELF-SERVE OPEN-AIR REFRIGERATOR	FEDERAL - IMSS120SC-3 (STANDARD SELF CONTAINTED)	1	208 V	1	30.0 A	N/A	FLUSH		JUNCTION BOX
S-55	PRIMO CAPPUCCINO	WILBUR CURTIS - G3 PRMO PCGT5	1	120 V	1	15.0 A	5-20	FLUSH		RECEPTACLES
S-56	HOUSE COMPUTER		2	120 V	1	3.0 A	5-20	FLUSH		RECEPTACLE
S-57C	HOT WATER DISPENSER	BUNN - H5X ELEMENT SST	1	120 V	1	15.4 A	5-20	FLUSH		RECEPTACLE
S-58	FROZEN BEVERAGE DISPENSER	BUNN - ULTRA-2 HP MANUAL FILL PRODUCT #34000.0080	1	120 V	1	12.0 A	5-15	FLUSH		RECEPTACLE

LIGHT FIXTURE SCHEDULE

TYPE	MANUFACTURER	CATALOG NUMBER	DESCRIPTION	Elec_Manual Entry Schedule Voltage	WATTS	MOUNTING	REMARKS
1B	LSI	ELFP22 LED 50 UE	2X2 LED RECESSED FIXTURE	120	36	RECESSED	ACRLYIC LENS
1BE	LSI	ELFP22 LED 50 UE	2X2 LED RECESSED FIXTURE	120	36	RECESSED	ACRLYIC LENS
D	EATON	RL5602H12950	6" LED CAN LIGHT	120	17.6	RECESSED	
E	LITHONIA	STL4 48L EZ1 LP850	1 X 4 LED VANITY LIGHT FOR BATHROOMS	120	50	WALL	
EM3	LITHONIA	ELA LED T WP M12	EMERGENCY LIGHT	9.6	1	CEILING / WALL	REMOTE EMERGENCY FIXTURE
EM5	HUBBELL	LG125S	INVERTER	120	110	SURFACE	MOUNT BOTTOM AT 7'-0" AFF
EM6	HUBBELL	DLS 400 120 A 20 01	INVERTER	120	400	SURFACE	MOUNT BOTTOM AT 7'-0" AFF
KK	COOPER	GWC-AF-01-LED-E1-T4FT-BZ-7050	WALL PACK	120	59	WALL	MOUNT CENTER @ 20'-11" AFF
MM	TMS LIGHTING	QS-4W O 15LED 40K 120 WM BR	FORTE WALL QUICKSHIP	120	15	WALL	MOUNT ARM CENTER @ 14'-6" AFF
S4	EATON	V4T2-LD4-6-UNV-L850-CD1-WL-U	4' LINEAR VAPORTITE LED STRIP LIGHT	120	57.3	SURFACE	MOUNT TO BOTTOM OF STRUCTURE
S4E	EATON	V4T2-LD4-6-UNV-EL10W-L850-CD1-WL-U	4' LINEAR VAPORTITE LED EMERGENCY STRIP LIGHT	120	57.3	SURFACE	MOUNT TO BOTTOM OF STRUCTURE (NOTE 9)
SA4	PINNACLE	LD6DIA70-840HO-48-AC120ST-U-OL1-1-0-W-CRF190134	LINEAR SUSPEND, PROVIDE VARIOUS LENGHTS AS SHOWN ON PLANS. PROVIDE CONNECTORS AND MOUNTING ACCESSORIES AS REQUIRED	120	6.4 W/FT	PENDANT	PROVIDE CUSTOM 30" OR 90" CORNER PIECES TO COMPLETE SHAPES AS SHOWN ON PLANS. MOUNT BOTTOM @ 10'-" AFF.
SA6	PINNACLE	LD6DIA70-840HO-72-AC120ST-U-OL1-1-0-W-CRF190134	LINEAR SUSPEND, PROVIDE VARIOUS LENGHTS AS SHOWN ON PLANS. PROVIDE CONNECTORS AND MOUNTING ACCESSORIES AS REQUIRED	120	6.4 W/FT	PENDANT	PROVIDE CUSTOM 30" OR 90" CORNER PIECES TO COMPLETE SHAPES AS SHOWN ON PLANS. MOUNT BOTTOM @ 10'-" AFF.
SA7	PINNACLE	LD6DIA70-840HO-84-AC120ST-U-OL1-1-0-W-CRF190134	LINEAR SUSPEND, PROVIDE VARIOUS LENGHTS AS SHOWN ON PLANS. PROVIDE CONNECTORS AND MOUNTING ACCESSORIES AS REQUIRED	120	6.4 W/FT	PENDANT	PROVIDE CUSTOM 30" OR 90" CORNER PIECES TO COMPLETE SHAPES AS SHOWN ON PLANS. MOUNT BOTTOM @ 10'-" AFF.
SA8	PINNACLE	LD6DIA70-840HO-96-AC120ST-U-OL1-1-0-W-CRF190134	LINEAR SUSPEND, PROVIDE VARIOUS LENGHTS AS SHOWN ON PLANS. PROVIDE CONNECTORS AND MOUNTING ACCESSORIES AS REQUIRED	120	6.4 W/FT	PENDANT	PROVIDE CUSTOM 30" OR 90" CORNER PIECES TO COMPLETE SHAPES AS SHOWN ON PLANS. MOUNT BOTTOM @ 10'-" AFF.
SB	LITHONIA	JCBL 1200LM ACFR MVOLT GZ10 40K 80CRI PM DWHXD	PENDANT	120	84	PENDANT	MOUNT BOTTOM AT 10'-6" AFF
SD	HALO COMM	HC4 40 D010 HM4 34 840 41 ND H	6" LED CAN LIGHT	120	14	RECESSED	
SE	VANTAGE	V2COR U 0740K L2070 SGC M WHT NCFAQ	6" LED CAN LIGHT	120	8	RECESSED	
SF	COOPER	L651P	HALO POWER TRACK, PROVIDE VARIOUS RUN LENGTHS AS SHOWSN ON PLANS	120		PENDANT	MOUNT TRACK @ 10'-6" AFF. PROVIDE CONNECTORS AND MOUNTING ACCESS AS REQUIRED FOR COMPLETE INSTALLATION.
SG1	PINNACLE	EX3D WHE N 840HO 18 WA U OL1 1 0 S	DIRECT LINEAR	120	137	WALL	SEE PLANS FOR PATTERN LENGTHS, PROVIDE EXTENSION SECTIONS AND CORNER PIECES AS NECESSAY
SG2	PINNACLE	EX3D WHE N 840HO 22 WA U OL1 1 0 S	DIRECT LINEAR	120	167	WALL	SEE PLANS FOR PATTERN LENGTHS, PROVIDE EXTENSION SECTIONS AND CORNER PIECES AS NECESSAY
SG3	PINNACLE	EX3D WHE N 840HO 12 WA U OL1 1 0 S	DIRECT LINEAR	120	92	WALL	(NOTE 10)
SH1	PINNACLE	EX3D WHE N 840HO 16 S U OL1 1 0 S	DIRECT LINEAR	120	119	SURFACE	
SH2	PINNACLE	EX3D WHE N 840HO 20 S U OL1 1 0 S	DIRECT LINEAR	120	148	SURFACE	
SK	ECOSENSE	SCD-X-48-40-MULT	COVE LIGHTING, LINE VOLTAGE, PROVIDE RUN LENGTHS AS SHOWN ON PLANS	120	8W/FT	COVE TRACK	PROVIDE ALL COMPONENTS NECESSARY FOR A COMPLETE SYSTEM
SN	COOPER	HC430D1O-HM434835-41NDW	RECESSED CAN LIGHT	120	27.2	RECESSED	
T4	EATON	4SNLED-LD5-64HL-UNV-L850-CD1-LOV-U	4' LINEAR LED STRIP LIGHT - HIGH OUTPUT	120	43	SURFACE	MOUNT TO BOTTOM OF STRUCTURE
T4E	EATON	4SNLED-LD5-64HL-UNV-L850-CD1-EL14W-LOV-U	4' LINEAR LED STRIP LIGHT - EMERGENCY	120	43	SURFACE	MOUNT TO BOTTOM OF STRUCTURE (NOTE 2)
X	LITHONIA	LHQM LED R HO M6	EXIT / EMERGENCY LIGHT	120	5	CEILING / WALL	EMERGENCY FIXTURE WITH 90 MINUTE BATTERY BACKUP
X3	LITHONIA	LRP 1 RMR 120/277 EL N	EXIT SIGN	120	4	RECESSED	

LIGHTING FIXTURE SCHEDULE GENERAL NOTES

1. LIGHT FIXTURES TO BE PROVIDED BY OWNER, INSTALLED AND CONNECTED BY ELECTRICAL CONTRACTOR.
2. PROVIDE ARROWS AND FACES AS INDICATED ON THE DRAWINGS.
3. ELECTRICAL CONTRACTOR SHALL VERIFY ALL FIXTURE LOCATIONS WITH ARCHITECTURAL ELEVATIONS.
4. ELECTRICAL CONTRACTOR SHALL INSTALL ALL CEILING MOUNTED LIGHTING FIXTURES IN LOCATIONS AS INDICATED ON THE ARCHITECTURAL REFLECTED CEILING PLAN.
5. GENERAL CONTRACTOR SHALL PROVIDE FIREPROOFING AROUND RECESSED FIXTURES INSTALLED IN FIRE RATED CEILING PER U.L. REQUIREMENTS, ELECTRICAL CONTRACTOR SHALL COORDINATE.
6. ALL LIGHT FIXTURES SHALL BE SECURED TO THE CEILING FRAMING SYSTEM BY MECHANICAL MEANS (SUCH AS BOLTS, SCREWS, OR RIVETS) OR BY CLIPS IDENTIFIED FOR USE WITH THE TYPE OF CEILING, FRAMING MEMBER, AND LIGHT FIXTURE.
7. EMERGENCY LIGHTS SHALL HUG CEILINGS. IN NON-CEILING STORAGE ROOMS, LOCATE BOTTOM OF FIXTURES AT 12'-0" AFF.

LIGHTING FIXTURE SCHEDULE KEYNOTES

1. PROVIDE DRYWALL FRAME KIT.
2. EMERGENCY FIXTURE WITH EMERGENCY BATTERY.

HFA
HARRISON FRENCH & ASSOCIATES, LTD
t 479.273.7780
1705 S. Walton Blvd., Suite 3
Bentonville, Arkansas 72712
www.hfa-ae.com

STIPULATION FOR REUSE
THIS DRAWING WAS PREPARED FOR USE ON A SPECIFIC SITE AT NICHOLSON, MS CONTEMPORANEOUSLY WITH ITS ISSUE DATE ON 2/7/2023 , AND IT IS NOT SUITABLE FOR USE ON A DIFFERENT PROJECT SITE OR AT A LATER TIME. USE OF THIS DRAWING FOR REFERENCE OR EXAMPLE ON ANOTHER PROJECT REQUIRES THE SERVICES OF PROPERLY LICENSED ARCHITECTS AND ENGINEERS. REPRODUCTION OF THIS DRAWING FOR REUSE ON ANOTHER PROJECT IS NOT AUTHORIZED AND MAY BE CONTRARY TO THE LAW.

Love's
STORE NUMBER: 860
I-59, EXIT 1
NICHOLSON, MS 39466
JOB NUMBER: 03-23-30009
TIER 1 180

ISSUE BLOCK

CHECKED BY: CAR
DRAWN BY: SED
DOCUMENT DATE: 2/7/2023
PROTO: TIER 1 180
PROTO CYCLE: Q4 - 2022

2023.02.07 14:23:54-06'00'

ELECTRICAL EQUIPMENT AND FIXTURE SCHEDULES

SHEET:
E611

2/7/2023 1:07:12 PM
C:\Users\sam.dempster\Documents\2021 Revit Projects\Loves_Nicholson, MS_MEP_T2_180_v21_HFA.Sam.Dempster.rvt
4600-E611-ELECTRICAL EQUIPMENT AND FIXTURE SCHEDULES