

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

P.O. Box 2830

985-649-5832
FAX 985-641-5950

August 10, 2015

John Kendrick
Textron Marine & Land
Environmental Health and Safety
252 Stone Road
Slidell, LA 70458

RE: Safety Harness Support system Calculations

Dear John,

Dammon Engineering was contacted to determine the method of attachment for Fall Protection safety Harness devices at Textron's Stone Road facility in Slidell. This facility consists of one large building with a low bay side and a high bay side. This support system shall not be used to support anything other than workers on a safety harness. Do not use the support system for any type of equipment or material handling. Install two cable clamps at each end of the cable for safety. All calculations were based the assumption that each person, with gear, being supported weighed 250 pounds.

Low Bay:

The proposed system was analyzed to support either 2 or 3 persons between spans.


- The cable shall be installed directly over the middle of the vehicle(s) being serviced.
- The cable tie shall be installed on the upper ½ portion of the beam.
- The cable shall be a minimum of 6x19 wire rope with a diameter of ½ " to support 2 persons or ¾" to support 3 persons between each span.

High Bay:

The proposed system was analyzed to support either 2 or 3 persons between spans.


- The cable shall be installed directly over the middle of the vehicle(s) being serviced.
- The cable shall be continuous from the east to west walls and cable ties shall be installed at each intermediate girder to support tension in both directions.
- The cable shall be a minimum of 6x19 wire rope with a diameter of 7/16 " to support 2 persons or 5/8" to support 3 persons between each span.

If you have any questions, or require any additional information, please don't hesitate to call.



Sincerely,
Brian Mistich, P.E.





1 MANUFACTURING SITE PLAN

SCALE: N.T.S.



BAM 8/10/2015

ADDITIONS AND RENOVATIONS:
TEXTRON
 Marine & Land Systems
 252 STONE ROAD
 SLIDELL, LOUISIANA

NO.	DESCRIPTION	DATE


SEAL:

SHEET TITLE:

DRAWING NUMBER:
S-1


DAMMON
 ENGINEERS & ARCHITECTS
Architects & Engineers

Chief Engineer: Brian Mistich, PE
 554 Old Spanish Trail
 Slidell, LA 70468
 www.dammonengineering.com
 info@dammonengineering.com
 PH: 985.649.3832
 FX: 985.649.1258



2 HIGH BAY FALL PROTECTION SAFETY CABLE

SCALE: N.T.S. ADDITIONAL BRACING AND ATTACHMENT AT JOIST GIRDERS



1 LOW BAY FALL PROTECTION SAFETY CABLE

SCALE: N.T.S.



BAM 8/10/2015

DAMMON
 ENGINEERING, INC.
Architects & Engineers
 www.dammonengineering.com
 info@dammon.com
 Ph: 985.649.8332
 Fax: 985.641.3950
 Chief Engineer: Brian Mistich, PE
 854 Old Spanish Trail
 Slidell, LA 70688

#	DESCRIPTION	DATE

ADDITIONS AND RENOVATIONS:
TEXTRON
 Marine & Land Systems
 252 STONE ROAD
 SLIDELL, LOUISIANA
 JOB No: DATE: 11.27.2015
 DRAWN BY: CHECKED BY:

SHEET TITLE:

DRAWING NUMBER:

S-2

SHEET No: 1 of 2