



LEGEND

- Dry or frost proof hydrant with fire department pumper connection (number of horns indicates number of hose outlets).
- Check valve (Detector check or back flow preventer when indicated).
- Automatic sprinkler point of distribution.
- Outside screw and yoke valve (OS&Y).
- Alarm check valve.
- Deluge valve, rate of rise or preaction type valves.
- Wall type post indicating valve.
- Fire pump.
- IBV Indicating butterfly valve.
- Post indicating valve (PIV) or Post indicating gate valve.
- Fire department connection.
- Fire service meter.
- Inspector's test valve.
- Mill Use/Domestic service pump, Meter, Flowmeter (As noted on plan).
- Gate valve, non-rising stem, pressure relief valve (PRV), quick opening valve (COV) or as noted on plan.
- Transformer not owned by the insured.

SPRINKLER SYSTEM DATA

| RISER LOCATION | Type | Spacing (ft) | Temp (°F) | Orif. (in.) | HYDRAULICALLY DESIGNED SYSTEM DATA | | |
|----------------|------|--------------|-----------|-------------|------------------------------------|------------|--------------|
| | | | | | Design Area (sq ft) or No. of Hds | Flow (gpm) | Press. (psi) |
| No 3 | | | | 0.25 | 3,000 | 800 | 37 |
| No 3A | | | | 0.23 | 3,000 | 820 | 67 |
| No 9 | | | | 0.30 | 2,700 | 900 | 75 |
| No 10 1st Flr | | | | 0.30 | 2,700 | 890 | 95 |
| No 10 2nd Flr | | | | 0.10 | 1,500 | 160 | 49 |
| | | | | 0.35 | 1,560 | 570 | 38 |

REVISIONS

| DR | CH | DATE | CHANGES MADE |
|-----|-----|-----------|---------------------------------------------------------|
| RDR | | Mar-05-15 | For Regular Risk Evaluation of D.K. Glaviano, Feb-19-15 |
| RNL | JRD | Oct-10-13 | For Regular Risk Evaluation of D.K. Glaviano, Oct-2-13 |

Textron Inc.
"Textron Systems"
"Marine & Land Systems-Textron Marine & Land Systems"
 New Orleans, Louisiana

Sketch From D. K. Glaviano
 October 2, 2013
 Scale: 1in = 100ft
 By RNL

FACTORY MUTUAL INSURANCE COMPANY
 Engineering Plan Services
 270 CENTRAL AVENUE, JOHNSTON, RI 02810-4949

INDEX
087700.65
1/1

