

**STATE OF LOUISIANA**  
Department of Public Safety and Corrections  
Office of State Fire Marshal Code Enforcement and Building Safety  
8181 Independence Boulevard  
Baton Rouge, Louisiana 70806  
225-925-4920

H "BUTCH" BROWNING  
FIRE MARSHAL

**FIRE ALARM SYSTEM**

ROBERT WILTSE  
DAMMON ENGINEERING INC  
1095 FLORIDA AVE  
SLIDELL, LA 70458-0000

RE: P0349833  
INSUL-TECH  
120 HERMAN DR  
BELLE CHASSE, LA 70037

NFPA 101, 2006

BUSINESS

Dear Applicant:

The fire alarm system for the above referenced project has been reviewed for compliance with NFPA 72 as shown on the drawings.

This is to advise that we have reviewed the drawings and specifications for the proposed Fire Alarm system and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

---

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

1. **The signaling system is a Remote Supervising Station system and shall conform with the provisions of NFPA 72:8-4.**
2. **101:9.6.3.7 Audible alarm indicating appliances shall be effectively heard above the average ambient sound level occurring under normal conditions of occupancy.**
3. **NFPA 72:4.5.2.3 The owner's manual, the installation instructions and as-built record drawings shall be given to the owner upon final acceptance of the system.**
4. **NOTE: Please enclose a copy of this letter with future submittals or other correspondence pertaining to this project.**

Changes to construction in the field which are not consistent with the reviewed documents are not authorized unless reviewed by this office for compliance with Code. Modifications to reviewed plans must be submitted to this office by the Architect/Civil Engineer for review prior to final inspection. If an Architect or Civil Engineer is not required by RS 37:155, revisions shall be submitted by the Owner. Submittals shall include plans, completed application, a minimum \$75.00 review fee, and a copy of the most current plan review letter.

Jul 23, 2008  
P0349833 - PAGE 1

This review is based on the information submitted concerning the fire alarm system in the referenced facility. This review shall in no way permit and/or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations.

**Occupancy of the project is permitted only upon the receipt of Contractor's Material & Test Certificate as per NFPA 13, Fire Alarm System Certificate and Description as per NFPA 72, or other certification as required by the applicable codes and a satisfactory inspection of the completed construction had been made by this office.**

**To arrange for inspection of the project, please contact the District Office at the phone number below two (2) to three (3) weeks in advance. The plans stamped reviewed by this office must be available on job site at time of inspection. Certificate of completion must be provided to the inspecting Deputy for final inspection.**

This review is valid for 180 days from the date of this letter. Construction permits must be issued and/or construction must commence within this time period.

REVIEWED BY:  
OTIS RAMKE  
ARCHITECT

CC:  
Grovie Properties Llc  
Priority Systems Inc  
Property Insurance Association\*  
Sheila Robeaux  
New Orleans District\* 5042194600