

7676
1891

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

HENRY H. FRY
DEPUTY ASSISTANT SECRETARY

RENOVATION

EDWARD GREMILLION, P E, C E
DAMMON ENGINEERING, INC
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0323364
WEST SURGI SUITE 7-8
1030 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

NFPA 101, 2003

BUSINESS

Dear Applicant:

This is to advise that we have reviewed the drawings and specifications for the subject proposed construction and have determined that they appear to satisfactorily comply with the adopted laws, codes, rules and regulations of The State Fire Marshal subject to the following requirements:

NOTE: THE COMMENTS LISTED BELOW IDENTIFY APPARENT DEFICIENCIES DETECTED IN OUR REVIEW OF THE DOCUMENTS SUBMITTED.

1. **NFPA 10:5.1.4 Provide portable fire extinguishers within the following travel distances (See Tables 10:5.2.1 and 5.3.1);**
 - a) **Travel distance to a fire extinguisher shall not exceed 75 feet for Class A, C and D fires.**

NOTE: THE FOLLOWING COMMENTS IDENTIFY ISSUES FOR INFORMATIONAL AND CAUTIONARY PURPOSES OR ISSUES THAT COULD NOT BE VERIFIED IN THE SUBMITTED DOCUMENTS.

2. **LRS 40:1731-(Effective 8/15/95) Provide access to persons with disabilities in accordance with ADA-AG (Accessibility Guidelines - September 1994). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. Compliance with state regulations and requirements does not guarantee compliance with federal law. Particular deficiencies and paragraph references are noted as follows:**
 - a) **4.5 Ground and floor surfaces shall be stable, firm, and slip-resistant.**
 - b) **4.5.2 Thresholds shall comply with requirements of this section regarding changes in level. (Not more than 1/2" height and beveled if over 1/4").**

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

March 12, 2007

Mr. Gordon Cameron
Office of State Fire Marshal
8181 Florida Blvd.
Baton Rouge, LA 70806

RE: P.O. 323364
West Surgi Suites 7-8

Dear Mr. Cameron,

With regard to the above referenced project, we are requesting that the name and address be changed on your review letter.

The correct name of the project is Kaufmann Office/Warehouse and the correct address is 1040 Old Spanish Trail, Suites 7 & 8, Slidell, LA 70458.

We appreciate your help with this matter. If you could fax a corrected letter to us at 985-641-5950, or email it to dammoneng@bellsouth.net, we would greatly appreciate it.

If you have any questions, or require any additional information, please feel free to call.

Sincerely,
Chuck Dammon
VP/Project Manager