

## Electrical Load Summary

Project Name: Blueline Wash Rack Bldg  
 Project Address: 2450 Destrehan Ave.  
 City / Town: Harvey, LA 70058

Intended Use: Wash Rack Equipment

Requested Service: 240 Volts 1 Phase 3 Wires

Service Entrance Size: 200 Amps

HVAC Tonnage: 0 Tons

Largest Motor: 1.5 HP (Note: Motors above 20 hp may require reduced Voltage starting and are never recommended for use with 1 20/240V, 3  $\phi$ , 4W services.)

Total Building Square Footage: 560 Square Feet

Individual Unit Square Footage: 560 Square Feet (Multiple Occupancy)

Individual Unit Designation: . (Multiple Occupancy)

277V / 480V

120V / 240V

LOAD SOURCE	1 $\phi$ - kVA	3 $\phi$ - kVA	or	1 $\phi$ - kW	3 $\phi$ - kW
Building Lighting			or	1.2	
Electric Water Heating			or		
Heat Pump			or		
Supplemental Heat System			or		
Air Conditioning			or		
Electrical Heating (Circle - Primary / Secondary)			or		
Cooking			or		
Refrigeration			or		
Receptacles (Standard)			or		
Receptacles (Computer)			or		
Laundry Cleaning Equipment			or		
Parking Lot / Exterior Lighting			or		
Miscellaneous			or		
Other (Specify) ESD WASHRACK CONTROL PANEL			or	28.0	