


MEZZANINE FLOOR PLAN
SCALE = 1/4"=1'-0"

FIRE SUPPRESSION EQUIPMENT NOTES:

1. CONTRACTOR TO EMPLOY A LICENSED SPRINKLER SYSTEM COMPANY TO INSURE THE EXISTING WET SPRINKLER HEAD LOCATIONS MEET CODE WITH THE NEW CONSTRUCTION.

GENERAL NOTES:

1. CONTRACTOR TO VERIFY ALL SITE CONDITIONS AND ALL EXISTING DIMENSIONS PRIOR TO CONSTRUCTION. THEY ARE APPROXIMATE AND NOT PURPORTED TO BE EXACT. CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND MUST CONTAIN CORRECT DIMENSIONS AND CONDITIONS.
2. MATERIALS SHALL BE NEW AND U.L. LISTED.
3. STRUCTURAL STEEL SHALL MEET A.I.S.C. SPECIFICATIONS.
4. STEEL SHALL BE A36.
5. ALL STEEL SHALL BE GALVANNEAL.
6. ALL WELDING SHALL BE PERFORMED IN ACCORDANCE WITH AWS D1.1.
7. ALL WELDING SHALL BE APPROVED BY LOCAL INSPECTORS.
8. CONTRACTOR SHALL GUARANTEE WORK FOR ONE YEAR.
9. CONTRACTOR SHALL FURNISH WATER AND POWER TO ALL WORK AREAS.
10. PROVIDE CLEANUP ON A REGULAR BASIS. STORE NO TRASH IN THE BUILDING.
11. ALL WORK SHALL COMPLY WITH THE LATEST EDITION OF ALL LOCAL, STATE AND FEDERAL CODES THAT COVER THE SECTION OF WORK BEING CONSTRUCTED.
12. PROVIDE PORTABLE FIRE EXTINGUISHERS IN ACCORDANCE WITH NFPA 10. SEE APPENDIX "E" OF NFPA 10 FOR DISTRIBUTION OF EXTINGUISHERS.
13. REGULATIONS: AT ALL TIMES DURING WELDING AND TORCH CUTTING IN THE EXISTING BUILDING, THE CONTRACTOR SHALL HAVE ADEQUATE FIRE FIGHTING EQUIPMENT ON HAND TO PREVENT AND CONTROL ANY FIRE. THE WELDING, THE WELDING AND TORCH CUTTING PROCESS SHALL BE CLOSELY OBSERVED AND MONITORED BY THE CONTRACTOR.
14. CONTRACTOR SHALL BE RESPONSIBLE FOR THE IGNITION OF ANY COMBUSTIBLES IN THE CONSTRUCTION AREA. OBSERVATIONS SHALL BE MADE FOR AT LEAST 4 HOURS AFTER WELDING OR TORCH CUTTING TO PREVENT PROVIDE ADEQUATE VENTILATION TO TOTALLY EXHAUST WELDING FUMES OUT OF THE CONSTRUCTION AREA TO PREVENT THE BUILDING.
15. ENGINEER SHALL APPROVE, AND CONTRACTOR SHALL SELECT AND PAY FOR, THE WELDING LABORATORY TO REVIEW WELDERS QUALIFICATIONS AND CHECK ALL STRUCTURAL STEEL CONNECTIONS IN FIELD.
16. CONTRACTOR SHALL PROVIDE ALL MATERIALS TO BE FURNISHED TO THE ARCHITECT FOR STRUCTURAL STEEL.
17. ADHESIVE TYPE ANCHOR BOLTS ARE HILT FASTENING SYSTEMS THAT ARE NOT TO BE USED FOR ANY REINFORCING. THE CONTRACTOR SHALL LOCATE REINFORCING CAGES BY MEANS OF SMALL DRILLED PILOT HOLES OR OFFSET TO VOID DAMAGE. LOCATION OF THE ANCHOR BOLT AND STIFFENING PLATES FROM A FIELD TEMPLATE AND COMPLETE THE INSTALLATION USING HILTI HIT HY-150 ANCHOR BOLT SYSTEM.
18. CONTRACTOR SHALL FIELD ALL SPICES TO BE SHOWN ON SHOP DRAWINGS. (SEE DETAIL BELOW)



SCALE(S) NOTED
FILE:
JOB NO. 1745
DATE 07-05-06
SHEET
A-1

MEZZANINE THREE LAKEWAY

DAMMON ENGINEERING, INC.

1095 FLORIDA AVENUE 985-849-5882 SLIDELL, LA. 70468
DAMMONENGINEERING.COM

MEZZANINE FLOOR PLAN

PEOPLES HEALTH NETWORK
3838 N. CAUSEWAY BLVD.
METAIRIE, LA 70002