

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

HENRY H. FRY
DEPUTY ASSISTANT SECRETARY

AMENDED LETTER

EMMETT DAMMON, P.E., E.E
DAMMON ENGINEERING
1095 FLORIDA AVE
SLIDELL, LA 70458-0000

RE: P0311858
PEOPLES HEALTH NETWORK
GENERATOR
3838 N CAUSWAY BLVD
METAIRIE, LA 70001-0000

NFPA 101, 2003

BUSINESS
STORAGE
FUEL STORAGE TANK

Dear Applicant:

This is to advise that the previous review letter dated 07/24/2006 for this project is hereby amended as follows:

1. **Since the exterior wall of this "Cut-off Room" is not toward another part of this building, nor toward any other nearby building, the words ", exterior walls" is removed from Item 17b of the review letter dated July 24, 2006.**
2. **NOTE: Please enclose a copy of this letter and the review letter dated July 24, 2006, with future submittals or other correspondence pertaining to this project.**

This review applies to the work indicated on the drawings or specifications.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations in accordance with R.S. 40:1574.1(B).

The above amended review is valid if construction starts within 180 days from the above date of the original review letter.

Occupancy of the project will not be permitted until we receive the completed certificate and a satisfactory inspection of the completed construction has been made by this office.

To arrange for inspection of the project, please contact the District Office at the phone number below, two (2) to three (3) weeks in advance. Approved plans must be available on job site at time of inspection. Certificate of completion must be provided to inspecting Deputy for final inspection.

REVIEWED BY:
WILLIAM JENSEN
ARCHITECT

CC:

Cantrelle Braithwaite

Jefferson Parish Fire Prevention

Sam Vanover*

New Orleans District* 5042194600