

Automatic Sprinkler System Modifications REQUEST FOR EXEMPTION

PLEASE PRINT CLEARLY OR TYPE INFORMATION

LOUISIANA DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
OFFICE OF STATE FIRE MARSHAL
8181 INDEPENDENCE BOULEVARD
BATON ROUGE, LOUISIANA 70806
PHONE (225) 925-4920 FAX (225) 925-4414
WEB SITE: www.dps.state.la.us/sfm

REVIEW FEE
\$20.00

DATE OF APPLICATION **16 APRIL 2008**
STATE FIRE MARSHAL ARCHITECTURAL REVIEW NUMBER
PO 311858

SHREVEPORT 888-634-7682
 NEW ORLEANS 888-634-7689
 LAFAYETTE 800-554-0006
 BATON ROUGE 800-256-5452
 HEALTH CARE
 CONTACT THE INDICATED DISTRICT OFFICE FOR FINAL INSPECTION:

PROJECT TITLE (Name of Business) GENERATOR ROOM		PROJECT FLOOR 2
NAME OF BUILDING/SHOPPING CENTER LAKEWAY III		TOTAL NO FLOORS IN BUILDING 26
PHYSICAL LOCATION OF PROJECT Inside City Limits <input checked="" type="checkbox"/> Outside City Limits <input type="checkbox"/>	ADDRESS (Street/Suite) 3828 N. CAUSWAY BLVD. CITY (In or Near) METAIRIE	EXEMPTION RESUBMITTAL? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> PREVIOUS REVIEW NUMBER:
	ZIP CODE 70002	PARISH JEFFERSON

PROFESSIONAL OF RECORD (P.O.R.) (If none, then MUST be Owner)

NAME Emmett G. Dammann	PHONE (985) 649-5832
MAILING ADDRESS (Street/P.O. Box) 1095 Florida Ave	FAX (985) 641-5950
CITY Slidell	STATE LA ZIP CODE 70458
P.O.R. LICENSE NO 8796	EMAIL ADDRESS edammann@bellsouth.net

SPRINKLER SYSTEM INFORMATION

OCCUPANCY CLASS (NFPA 101 Chapter)	HAZARD CLASS (PER NFPA 13) ORDINARY HAZARD	PUMP INFORMATION PRESSURE (psi) 110 FLOW (gpm) 1000	PLACARD INFORMATION GPM/SP OVER SF, WITH DEMAND OF PSI AT GPM AT
SYSTEM TYPE <input type="checkbox"/> WET <input checked="" type="checkbox"/> DRY	DESIGN TYPE <input checked="" type="checkbox"/> HYDRAULIC <input type="checkbox"/> PIPE SCHEDULE	MAIN REDUC. VAL. SET 165 psi PRESS. REDUC. VAL. SET 165 psi	
WATER SOURCE <input checked="" type="checkbox"/> MUNICIPAL <input type="checkbox"/> PRIVATE	WATER SUPPLY DATA (psi) STATIC RESIDUAL (psi)	FLOW (GPM) TEST DATE 1/1	
TOTAL NUMBER OF EXEMPTION SPRINKLERS 8	AREA COVERED BY THIS EXEMPTION (sq ft) 760	COST OF WORK TO BE DONE \$	NONE AVAILABLE
DESCRIPTION OF WORK REPLACE SIX (6) EXISTING SPRINKLER WITH HIGH TEMPERATURE HEADS (286°F). ADD TWO (2) NEW HIGH TEMP. SPRINKLERS DUE TO OBSTRUCTION BY GENERATOR.			
SPRINKLER MFG. RASCO	MODEL F1	TYPE UPRIGHT	TEMPERATURE: 286°F ORIFICE SIZE: K05.6
EFFECT ON SYSTEM NONE. COVERAGE MAINTAINED BY ADDITION OF NEW SPRINKLERS (AREA PER HEAD OF EXISTING & NEW LESS THAN EXISTING). CONNECT TO EXISTING CROSS MAIN FOR PIPE TO NEW HEADS. GENERATOR ROOM IS NOT IN PHYSICALLY REMOTE OR HVD. MOST OF THE ROOM IS NOT.			

SPRINKLER SYSTEM CONTRACTOR / ENGINEER / DESIGNER (not the POR)

NAME MARK S. TAYLOR	EMPLOYEE STATE LICENSE NO. E 1728
FIRM NAME AMERICAN SPRINKLER	FIRM MAILING ADDRESS P.O. BOX HARAHAN, LA 70
CONTACT NAME SAME	
FIRM LICENSE NUMBER F344	PHONE NO (504) 837-0572 FAX NO (504) 837-3253
	EMAIL ADDRESS mtaylor@i-55.com

SPFM	FOR FIRE MARSHAL USE ONLY	DATE RECEIVED	PROJECT NUMBER	REVIEW ARCHITECT
	<input type="checkbox"/> Accepted <input type="checkbox"/> Denied	Comments		

CC: Applicant Sprinkler Contractor SFM District Fire Prevention Bureau SPM Health Care High Rise File Pending File

spfm/revs/cdr - 4/1/2008