



July 20, 2018

Ms. Jie Gu P.E.,
Region IX Engineer
OPH

RE: Terra Bella Class C Swimming Pool
Covington, Louisiana

Ms. Gu,

Revisions to the plan have been made for the subject project.

1. The depth of the northeast end of the pool has been changed from 4 ft to 3.5 ft depth. This change reduces the volume of water inside the pool. The time required to turn-over the entire pool water capacity will be less than originally designed.
2. The ladder shown on the plan at the northern most corner of the pool has been changed to stairs. This change does not exceed the maximum spacing between entry/exits along the pool wall. The stair treads and risers meet all the requirements in the code. A handrail is included with the stairs to serve all treads and risers.

If you have any questions, or require additional information, please feel free to call.

Sincerely,

David Dammon
Dammon Engineering, Inc.