



GA FILE NO. WP 1072 GENERIC

ONE LAYER 5/8" TYPE X GYPSUM WALLBOARD OR GYPSUM VENEER
BASE APPLIED PARALLEL OR AT RIGHT ANGLES TO EACH SIDE OF
3-5/8" STEEL STUDS 24" O.C. WITH 1" TYPE S DRYWALL SCREWS 8"
O.C. AT VERTICAL JOINTS AND 12" O.C. AT FLOOR AND CEILING
RUNNERS AND INTERMEDIATE STUDS.

JOINTS STAGGERED 24" ON EACH SIDE AND ON OPPOSITE SIDES.
SOUND TESTED WITH 3-12" GLASS FIBER FRICTION FIT IN STUD
SPACE. (NON-LOAD BEARING)

1 HOUR FIRE 45 TO 49 STC SOUND



THICKNESS:
APPROX. WEIGHT:
FIRE TEST:

4-1 7/8"
6 PSF
SEE WP 1200

(FM WP-45, 6-19-68);
OSU T-1770, 8-61;
ULC T9T484, T9T500, T9T497,
8-12-81, ULC DESIGN W415)
SOUND TEST: NRCC 816-NV, 2-3-81