

EVALUATE NEW GAS SERVICE REQUIREMENTS AND UPGRADE METER AND SERVICE AS REQD.

EXISTING 2\"/>

RECONNECT TO 1\"/>

**PLUMBING PLAN**



SCALE 1/4" = 1'-0"


NOTE:  
FOR PLUMBING SCHEDULE ONE  
LINE DIAGRAM AND DETAILS SEE  
SHEET P-2.

EXISTING WALLS TO REMAIN

NOTE:  
PROVIDE COMPLETE OPERATING  
INSTALLATION OF ALL HIBACHI TABLES  
INCLUDING GAS, ELECTRIC, DUCT AND FIRE  
SUPPRESSION SYSTEMS. COORDINATE WITH  
ROASTER TECH SMOKELESS HIBACHI TABLE  
MODEL TQJ-08 AND TQJ-010. PROVIDE  
COMPLETE OPERATING FIRE SUPPRESSION  
SYSTEM EQUAL TO KIDDE VET CHEMICAL  
SYSTEM WHDR-260 TO INCLUDE ALL FIRE  
MARSHALL REVIEW DOCUMENTS.

**PLUMBING NOTES**

1. PROVIDE ALL LABOR, MATERIAL AND EQUIPMENT FOR A COMPLETE OPERATING SYSTEM. THE SYSTEM SHALL INCLUDE HOT AND COLD WATER PIPING, SEWER AND VENT PIPING, INSULATION, WATER HEATER, HANGERS, VALVES, SUPPORTS WITHOUT ANY RESTRICTIONS TO COLUMN, CUT AND PATCH AS REQUIRED TO INSTALL PIPES.
2. ALL WORK AND MATERIAL SHALL CONFORM STRICTLY TO THE LATEST LOCAL CITY, PARISH, STATE AND NATIONAL GOVERNING CODES, ELEVATIONS AND SIZES PRIOR TO COMMENCING ANY WORK. CONTRACTOR SHALL PAY NECESSARY FEES FOR THE UTILITIES CONNECTIONS.
3. CONTRACTOR IS RESPONSIBLE TO VERIFY THE EXISTING INVERTS AND SET NEW INVERTS OF SEWERAGE AND DRAINAGE PIPES.
4. SEWERAGE LINES 3-INCH AND SMALLER SHALL BE SLOPED 1/8" PER FOOT AND LINES 4-INCH AND LARGER SHALL BE 1/4" PER FOOT.
5. ALL PLUMBING SHALL BE CLOSE COORDINATED WITH STRUCTURAL TRADES. MECHANICAL SYSTEM AND ELECTRICAL TO INSURE NO TRADES WILL CONFLICT WITH EACH OTHER.
6. DO NOT SCALE DRAWINGS. SEE ARCHITECTURAL DRAWINGS FOR EXACT LOCATIONS OF DOORS, WINDOWS, WALLS, FIXTURES, ETC.
7. ALL WATER MAINS AND PIPING NOT SHOWN FOR CLARITY. ALL LOCATIONS FIELD VERIFIED.
8. DOMESTIC HOT AND COLD WATER PIPING AND FITTINGS UNDER SLAB SHALL BE ASTM B88 COPPER WATER TUBE TYPE K SOFT ANNEALED AND JOINTS SHALL BE ALLOWED UNDER THE SLAB.
9. ASTM B88 COPPER WATER TUBE TYPE HARD DRAWN WITH COPPER PRESSURE TYPE FITTINGS, ANSI B16.22. THE JOINTS SHALL BE SOLDERED TYING USING ASTM B32. ALLOY GRADE 95A (95-5) SOLDER.
10. SOIL WASTE VENT PIPING AND FITTINGS ABOVE THE SLAB SHALL BE SERVICE WEIGHT CAST IRON PIPE WITH BELL AND SPIGOT ENDS AND ONE PIECE NEOPRENE INSERT TYPE GASKET. USE PVC SCHEDULE 40 OR ABS DWV PIPES AND FITTINGS WHERE PERMITTED BY CODE.
11. ALL WATER PIPING AND FITTINGS ABOVE THE FLOOR SHALL BE ANNEALED COPPER TYPE K AND SHALL BE SOLDERED TO THE FLOOR PARTITIONS. SHALL BE FIRE CALLED. (PENETRATIONS THROUGH CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-E814.)
12. ALL PLUMBING LINES SHOWN ARE DIAGRAMMATIC.



**DAMMON**  
ENGINEERING, INC.

CHIEF ENGINEER  
EMMETT  
DAMMON, P.E.  
CHIEF ARCHITECT  
ROBERT  
WILTSE

1095 FLORIDA AVENUE  
SUDDL, LA, 70458  
OFFICE: 905-649-5832  
FAX: 905-641-5950

WEBSITE:  
WWW.DAMMONENGINEERING.COM  
EMAIL:  
DAMMONENG@BELLFLOW.NET

ARCHITECTURE  
ENGINEERING  
STUDIES  
PLANNING  
INVESTIGATION  
EXPERT WITNESS

RESTAURANT  
RENOVATION

OSAKA  
287 S. MORRISON BLVD.  
HAMMOND, LA

PLUMBING  
PLAN

REV:

SCALE: AS NOTED

JOB#: 1943

DATE: 7-25-08

SHEET 21

P-1

OF 22