



- GENERAL ELECTRICAL NOTES:**
1. PROVIDE UNSWITCHED CONDUCTOR FOR EMERGENCY FIXTURES AND EXIT SIGNS.
 2. INSTALL ALL EMERGENCY EXIT LIGHTS AND EXIT SIGNS AT 9'-0" OR JUST BELOW CEILING IN CASES WHERE CEILING IS LOWER THAN 9'-0".
 3. INTERCONNECT RESTROOM FAN WITH RESTROOM LIGHT AND SWITCH.
 4. PROVIDE MINIMUM OF (2)#12, (1)#12 GND. FOR ALL CIRCUITS.

- ELECTRICAL PLAN NOTES:**
- 1 HOMERUN CIRCUIT(S) THRU CONTACTOR CONTROLLED BY PHOTOCELL AND/OR TIME SWITCH. REFER TO CONTACTOR SCHEDULE ON SHEET E5 FOR CONTROL SEQUENCE.
 - 2 TIMESWITCH AND CONTACTORS FOR OVERIDE CONTROL OF LIGHTS. REFER TO CONTACTOR SCHEDULE ON SHEET E7 AND SPECIFICATIONS FOR ADDITIONAL INFORMATION.

1 LIGHTING FLOOR PLAN
SCALE: 1/8"=1'-0"

REVISION #1	FLS	BY

DDG DUPLANTIS DESIGN GROUP, PC
Respect. Integrity. Client Satisfaction. Excellence.
 THIBODAUX MANDEVILLE HOUSTON
 Civil Engineering • Site Development • Land Planning • Public Works Administration
 3347 West Lakeshore
 Thibodaux, Louisiana 70301
 Phone: 985.447.7009
 Fax: 985.447.7009

STAMP
 STATE OF LOUISIANA
 CRAIG R. LANHAM
 REG. NO. 25544
 PROFESSIONAL ENGINEER
 IN
 ELECTRICAL ENGINEERING
 SIGNATURE: _____ DATE: _____

PROPOSED RETAIL DEVELOPMENT
 CITY OF BOULTE
 ST. CHARLES PARISH, LOUISIANA
 FOR THE SPECTRA GROUP, INC.
 MEMPHIS, TENNESSEE

DRAWN FLS
 CHECKED
 DATE 8/13/07
 SCALE AS NOTED ON DWG
 PROJECT NO. 0750001106
 FILE 0750001106E1DWG
 SHEET

HENDERSON ENGINEERS
 8325 LEXA DRIVE
 LENOXA, KS 66214
 TEL 913.742.5000 FAX 913.742.5001
 www.hel-eng.com
 0750001106

E1