

DAMMON ENGINEERING, INC.

dammonengineering.com

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

January 13, 2012

To: Jay Lansou

REF: Marco's Pizza
9212 W. Judge Perez Dr.
Chalmette, LA 70043

Dear Mr. Lansou,

Per our meeting this morning Jan 13 2012, please be advised that Dammon Engineering approves the use of a metal stud framing system in lieu of the Steel Lintel as described on the plans for the above referenced project.

Please provide a metal stud framing system complete with Densglass sheathing, vapor barrier, and stucco finish in areas where existing CMU will be removed. Tie framing system into existing structural beam above opening and provide header as needed for new storefront wall system.

Sincerely,
Brandon Nowakowski
Dammon Engineering