Number 1

Number 2

Number 3

Number 4

Number 5

Number 6





General Note:

1. Blank areas of the floor plan represent areas that have bare concrete, ceramic tile, terrazo, wood or carpeted floors. In the case of carpeted floors, the substrate is considered to be of unknown composition unless otherwise stated.

Sheet Notes:

1. Carpeted Floor
2. Carpet installed over concrete.
3. PORTABLES ADDED TO CAMPUS; ASSUMED POSITIVE FOR ACM.



Scale 1" = 60'

SITE PLAN

PAGE 1

RITTER CONSULTING ENGINEERS LTD.
250 RIDGEWAY DRIVE, SUITE C-3
LAFAYETTE, LOUISIANA 70503
TELEPHONE (337) 984-8498 FAX (337) 984-8576

SLIDELL JUNIOR HIGH SCHOOL
DISTRIBUTION OF FLOOR TILE
2013 ASBESTOS REINSPECTION

DRAWN
CHECKED
REVISED

PROJECT
2013-7033

DATE
AUGUST 2013

SHEET 1

Legend: Types of Floor Tile. Red Pattern indicates positive test for asbestos.

1 12"FT: Beige w/ stringy light & dark streaks.
Only mastic is ACM.

2 12"FT: Green. Mastic also non ACM.

3 12"FT: Beige w/ stringy white & dark brown streaks.
Only mastic is ACM.

4 12"FT: Medium beige w/ white & dark brown streaks.
Mastic also non-ACM.

5 12"FT: Offwhite w/ gray accents.
Mastic also non-ACM.

6 12"FT: Chocolate brown w/ mottled pattern of colors.
Mastic also non-ACM.

7 12"FT: Tan w/ large light dark accents.
Mastic also non-ACM.

8 12"FT: Offwhite w/ light & dark accents.
Mastic also non-ACM.

9 9"FT: Tan w/ light & dark streaks.
Mastic also ACM.

10 12"FT: Offwhite w/ dark accents.
Mastic also non-ACM.

11 12"FT: Offwhite w/ sparse dark accents.
Mastic also non-ACM.

12 12"FT: Offwhite w/ olive green accents.
Only mastic is ACM.

13 12"FT: Green. Only mastic is ACM.

14 12"FT: A mix of offwhite, pink, black, & green.
Mastic also non-ACM.

15 12"FT: Green w/ light & dark accents.
Mastic also non-ACM.

16 12"FT: Beige w/ light & dark streaks.
Only the mastic is ACM.

17 12"FT: brown w/large light & dark accents
Only mastic is ACM.

18 9"FT: red. Mastic also ACM.

19 9"FT: gray w/white to streaks
Mastic also ACM.

SHEET	PROJECT	DRAWN			
2	2013-7033	CHECKED	SLIDELL JUNIOR HIGH SCHOOL DISTRIBUTION OF FLOOR TILE 2013 ASBESTOS REINSPECTION	RITTER CONSULTING ENGINEERS LTD. 250 RIDGEWAY DRIVE, SUITE C-3 LAFAYETTE, LOUISIANA 70503 TELEPHONE (337) 984-8498 FAX (337) 984-8576	PAGE 2
	DATE	REVISED			
	AUGUST 2013				





Legend:

Pipe run (radiant heat) insulated with ACM (on both straights and elbows)

Pipe run on (domestic water) which only the fittings and elbows are insulated with ACM (plaster).

60 0 60 120 180

Scale 1" = 60'

SITE PLAN

PAGE 3

RITTER CONSULTING ENGINEERS LTD.
250 RIDGEWAY DRIVE, SUITE C-3
LAFAYETTE, LOUISIANA 70503
TELEPHONE (337) 984-8498 FAX (337) 984-8576

SLIDELL JUNIOR HIGH SCHOOL
DISTRIBUTION OF ASBESTOS CONTAINING TSI
2013 ASBESTOS REINSPECTION

DRAWN LR
CHECKED
REVISED

PROJECT 2013-7033

DATE AUGUST 2013

SHEET 3





Legend (ACM in red)

- Trasite panels used in window and door assemblies.
- Transite panels used as roof deck.
- Transite panels used in walkways, soffits, entrance canopies.

60 0 60 120 180

Scale 1" = 60'

SITE PLAN

PAGE 4

RITTER CONSULTING ENGINEERS LTD.
250 RIDGEWAY DRIVE, SUITE C-3
LAFAYETTE, LOUISIANA 70503
TELEPHONE (337) 984-8498 FAX (337) 984-8576

SLIDELL JUNIOR HIGH SCHOOL
DISTRIBUTION OF TRANSITE
(KNOWN AND ASSUMED ACM)
2013 ASBESTOS REINSPECTION

DRAWN LR
CHECKED
REVISED

PROJECT 2013-7033

DATE AUGUST 2013

SHEET 4