



ELECTRICAL CONDUIT PLAN
SCALE: 1/4" = 1'-0"

- NOTES:**
1. SUPPORT CONDUIT ON UNISTRUT/THEADED ROD TRAPEZE, OR ON WALL BRACKETS. SUPPORTS SHALL BE SPACED 8' O.C. MAXIMUM, AND WITHIN 24" OF ALL CONDUIT BENDS.
 2. THIS SPECIFIC CONDUIT RUN SHALL BE EITHER RIGID GALVANIZED STEEL (RGS) CONDUIT, OR RIGID THREADED ALUMINUM. ALL CONNECTOR FITTINGS SHALL BE MEYER HUBS, OF MATERIAL TO MATCH THE CONDUIT USED. USE ALUMINUM THREAD LUBRICANT ON ALL ALUMINUM CONDUIT FITTINGS. RUN MINIMUM ELEVEN FEET (11') ABOVE FLOOR.

These plans and specifications have been prepared by me or under my close personal supervision, and to the best of my knowledge and belief, they meet all applicable codes and ordinances. I will not supervise the work.
Bruce D. Barton
 BRUCE D. BARTON, P.E.
 PROFESSIONAL ENGINEER
 STATE OF LOUISIANA
 REG. NO. 18226
 10/1/2012

| | |
|---|------------|
| CADD FILE NAME: | |
| REVISIONS | |
| REMARKS | |
| DATE | |
| APPD | |
| | |
| ALL SOUTH ENGINEERS, L.L.C. 652 PAPERWORTH AVENUE METAIRIE, LA 70005 504 922-2785 | |
| DESIGNED BY: | RAC |
| DRAWN BY: | EAO |
| CHECKED BY: | RAC |
| DATE: | 10/04/2012 |
| SCALE: | AS SHOWN |
| JOB NO. | 025-006-01 |
| PLAQUEMINES PARISH QUIET ROOMS PACKAGE NO. 2 DIAMOND PUMP STATION, HAYES PUMP STATION, GRAND DELIARD PUMP STATION, AND DUVIC PUMP STATION DIAMOND PUMP STATION ELECTRICAL CONDUIT PLAN | |
| SHEET NO. DM-E2 | |
| 21 OF 67 | |