



- NOTES:**
- FURNISH & INSTALL ONE 90A, 3-P CIRCUIT BREAKER IN EXISTING MAIN DISTRIBUTION PANEL POLE SPACES 32/34/36. CONNECT NEW FEEDER TO POLES 32 AND 36, TO GET POWER FROM PHASES A AND C. DO NOT CONNECT TO THE B PHASE "STINGER".

These plans and specifications have been prepared by me or under my close personal supervision, and to the best of my knowledge and belief, they meet all applicable codes and regulations. I will not supervise the work.

Bruce D. Barton
 Bruce D. Barton, P.E.
 10/1/2012

CADD FILE NAME:	
REVISIONS	APPD
REMARKS	
DATE:	
ALL SOUTH ENGINEERS, L.L.C. 6522 PAPPWORTH AVENUE METAIRIE, LA 70005 504 922-2785	
DESIGNED BY:	RAC
DATE:	10/04/2012
DRAWN BY:	EAO
SCALE:	AS SHOWN
CHECKED BY:	RAC
JOB NO.:	025-006-01
PLAQUEMINES PARISH QUIET ROOMS PACKAGE NO. 2 DIAMOND PUMP STATION, HAYES PUMP STATION, GRAND DELIARD PUMP STATION, AND DUVIC PUMP STATION GRAND DELIARD PUMP STATION ELECTRICAL CONDUIT PLAN	
SHEET NO.:	GD-E2
49 OF 67	