



IRC REQUIREMENTS FOR ROOF COVERINGS

R1052.2 SLOPE: ASPHALT SHINGLES SHALL BE USED ONLY ON ROOF SLOPES OF TWO UNITS VERTICAL IN 12 UNITS HORIZONTAL (2:12) OR GREATER. FOR ROOF SLOPES FROM TWO UNITS VERTICAL IN 12 UNITS HORIZONTAL (2:12) UP TO FOUR UNITS VERTICAL IN 12 UNITS HORIZONTAL (4:12) DOUBLE UNDERLAYMENT APPLICATION IS REQUIRED IN ACCORDANCE WITH SECTION R1052.7.

R1052.6 ATTACHMENT: ASPHALT SHINGLES SHALL HAVE THE MINIMUM NUMBER OF FASTENERS REQUIRED BY THE MANUFACTURER. FOR NORMAL APPLICATION, ASPHALT SHINGLES SHALL BE SECURED TO THE ROOF WITH NOT LESS THAN FOUR FASTENERS PER STRIP SHINGLE OR TWO FASTENERS PER INDIVIDUAL SHINGLE. WHERE THE ROOF SLOPE EXCEEDS 20 UNITS VERTICAL IN 12 UNITS HORIZONTAL (20:12), SPECIAL METHODS OF FASTENING ARE REQUIRED. FOR ROOFS LOCATED WHERE THE BASIC WIND SPEED PER FIGURE R302.2(4) IS 10 MPH OR HIGHER, SPECIAL METHODS OF FASTENING ARE REQUIRED. SPECIAL FASTENING METHODS SHALL BE TESTED IN ACCORDANCE WITH ASTM D3661, CLASS F. ASPHALT SHINGLE WRAPPERS SHALL BEAR A LABEL INDICATING COMPLIANCE WITH ASTM D3661, CLASS F.

R1052.7 UNDERLAYMENT APPLICATION: FOR ROOF SLOPES FROM TWO UNITS VERTICAL IN 12 UNITS HORIZONTAL (2:12) PERCENT SLOPE, UP TO FOUR UNITS VERTICAL IN 12 UNITS HORIZONTAL (4:12) PERCENT SLOPE, UNDERLAYMENT SHALL BE TWO LAYERS APPLIED IN THE FOLLOWING MANNER. APPLY A 1/8-INCH STRIP OF UNDERLAYMENT FELT PARALLEL TO AND STARTING AT THE EAVES, FASTENED SUFFICIENTLY TO HOLD IN PLACE. STARTING AT THE EAVE, APPLY 36-INCH WIDE SHEETS OF UNDERLAYMENT, OVERLAPPING SUCCESSIVE SHEETS 11 INCHES, AND FASTENED SUFFICIENTLY TO HOLD IN PLACE. FOR ROOFS OF 4 UNITS VERTICAL IN 12 UNITS HORIZONTAL (4:12) PERCENT SLOPE OR GREATER, UNDERLAYMENT SHALL BE ONE LAYER APPLIED IN THE FOLLOWING MANNER. UNDERLAYMENT SHALL BE APPLIED SHINGLE FASHION, PARALLEL TO AND STARTING FROM THE EAVE AND LAPPED 2 INCHES, FASTENED SUFFICIENTLY TO HOLD IN PLACE. END LAPS SHALL BE OFFSET BY 6 FEET.

R1052.7.2 UNDERLAYMENT AND HIGH WIND: UNDERLAYMENT APPLIED IN AREAS SUBJECT TO HIGH WINDS (GREATER THAN 10 MPH PER FIGURE R302.2 (4)) SHALL BE APPLIED WITH CORROSION RESISTANT FASTENERS IN ACCORDANCE WITH MANUFACTURER'S INSTALLATION INSTRUCTIONS. FASTENERS ARE TO BE APPLIED ALONG THE OVERLAP NOT FARTHER THAN 36 INCHES (914 MM) ON CENTER.

ROOFING NOTES

- 1 ROOF SHEATHING
ALL ROOF SHEATHING SHALL BE 5/8" EXPOSURE 1 24/0 APA RATED PANELS. FASTEN WITH DURALIS AT 6" O.C. AT ALL TRUSS MEMBERS. USE 6X RING SHANK NAILS WITHIN 5'-0" OF ROOF EDGES.
- 2 ROOF UNDERLAYMENT
ROOF UNDERLAYMENT SHALL BE 15# FELT. UNDERLAYMENT SHALL BE INSTALLED WITH CORROSION RESISTANT FASTENERS SPACED AT 36" O.C. MAX.
- 3 ROOFING
ROOF COVERING SHALL BE ASPHALT SHINGLES, UNO. SHINGLES SHALL HAVE A 25 YEAR (MIN) LIFE. SHINGLES SHALL BE INSTALLED PER MANUFACTURER SPECIFICATIONS (6 NAILS/SHINGLE). SHINGLES SHALL BE CLASS F SHINGLES.
- 4 ROOF BRACING
SUPPORT RAFTERS AS REQUIRED TO LIMIT SPANS PER NOTES ON DWG. S-0 WITH PURLINS OF EQUAL SIZE AS RAFTERS SUPPORT PURLINS WITH 2X BRACING AT 4FT MAX SPACING. NOT ALL PURLINS & BRACING SHOWN.

ROOF PLAN

PLANS FOR:
GARY EVANS
LOT 99 & 100, LAKESHORE ESTATES
ST. TAMMANY PARISH, LA

DesignTech DATE
12-15-11
Residential Planners, Inc.
St. Tammany Parish, LA.
COVINGTON 985-871-7211 SLIDELL 985-847-0500

CODE	LIVING	AREA U.B.	INDEX
B3	3967	6676	9708

BY	DATE	BY	DATE
DMH	~	~	~

©Copyright 2011, as updated with by DesignTech Residential Planners, Inc. ALL RIGHTS RESERVED.
EMAIL: houseplans@designtechusa.com

ROOF PLAN
SCALE 1/4" = 1'-0"

A-3