

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	CAFETERIA 206	HP1	1	2340	SILV. TC		9						
2	CAFETERIA 208	HP1	3	3360	SILV. TC		10						
3	KITCHEN	HP1	5	1785	SILV. TC		11						
4	BLOG MAND LITS	HP1	7	1350	TC PC		12						
5	SITE - NORMAL	HP1	9	1725	TC PC		13						
6	SITE - EMERGENCY	EM1	5	2387	PC		14						
7							15						
8							16						

TOTAL WATTAGE 13747

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	CORRIDOR 205	HP3	1	975	SILV. TC PC								
2	CORRIDOR 206	HP3	1	975	SILV. TC PC								
3	CORRIDOR 102	HP3	3	2160	SILV. TC PC								
4	CLEVERSTORY	HP3	5	420	SILV. TC PC								
5	BLOG MAND LITS	HP3	5	540	TC PC								
6													
7													

TOTAL WATTAGE 5970

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	CORR. 154	HP5	1	1080	SILV. TC								
2	CORR. 154	HP5	1	855	SILV. TC PC								
3	OPEN SPACE	HP5	1	840	SILV. TC								
4	CLEVERSTORY	HP5	3	1800	SILV. TC PC								
5	BLOG MAND LITS	HP5	3	540	TC PC								
6													
7													

TOTAL WATTAGE 5115

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	CORRIDOR 314	2HP1	1	1170									
2	CLEVERSTORY	2HP1	1	1080									
3	CORRIDOR 300	2HP1	3	1620									
4	LOBBY	2HP1	3	420									
5	AUDITORIUM (TROFFER)	2HP1	5	2300									
6	AUDITORIUM (TROFFER)	2HP1	5	910									
7	AUDITORIUM (DOWNLITS)	2HP1	5	250									
8	AUDITORIUM (WALLWASH)	2HP1	5.0	200									

TOTAL WATTAGE 7750

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	CORRIDOR 302	HP2	1	720	SILV. TC		9						
2	CORRIDOR 302	HP2	1	480	SILV. TC PC		10						
3	CLEVERSTORY	HP2	1	2070	SILV. TC PC		11						
4	BLOG MAND LITS	HP2	7	1350	TC PC		12						
5							13						
6							14						
7							15						
8							16						

TOTAL WATTAGE 4630

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	MAIN LOBBY 100	HP4	1	1070	SILV. TC		9	RECEPTION 104	HP4	1	520	SILV. TC	
2	CORRIDOR 149	HP4	5	810	SILV. TC PC		10	RECEPTION 104	HP4	1	350	SILV. TC	
3	CORRIDOR 171	HP4	5	900	SILV. TC PC		11	CANOPY LIGHTS/SIGN	HP4	17	1230	TC PC	
4	CORRIDOR 111	HP4	1	720	SILV. TC		12	BLOG MAND LITS	HP4	19	990	TC PC	
5	LIBRARY STACKS	HP4	3	1270	SILV. TC		13						
6	LIBRARY 103	HP4	3	1400	SILV. TC		14						
7	LIBRARY RECEPTION	HP4	3	450	SILV. TC		15						
8	WAITING 103	HP4	1	525	SILV. TC		16						

TOTAL WATTAGE 9775

NOTES:

RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES	RELAY NO.	LOAD DESCRIPTION	DISTRIBUTION		WATTS	SWITCHES (PHOTOCELL/PH OCCUPANCY)	NOTES
		PANEL NUMBER	CCT NUMBER						PANEL NUMBER	CCT NUMBER			
1	GYM	HP5A	1	2375			9						
2	GYM	HP5A	3	2375			10						
3	GYM	HP5A	5	2375			11						
4	GYM	HP5A	7	2375			12						
5	GYM	HP5A	9	2375			13						
6	GYM	HP5A	11	2375			14						
7	LOBBY 208	HP5A	13	1785			15						
8	BLOG MAND LITS	HP5A	17.0	1350.0			16						

TOTAL WATTAGE 16655

NOTES:

LACHIN OUBRE & Associates
 ARCHITECTS PLANNERS
 PROJECT MANAGERS
 A PROFESSIONAL CORPORATION
 3000 West Esplanade Ave., Suite 302, Metairie, La. 70002
 Ph: 504-835-8013 Fax: 504-835-8034

NO.	DATE	DESCRIPTION
1	04/10/2008	BID/PERMIT SUBMISSION

ST. BERNARD PARISH SCHOOL BOARD
CHALMETTE ELEMENTARY SCHOOL
 75 WEST CHALMETTE CIRCLE
 CHALMETTE, LOUISIANA

ISSUED TITLE: LIGHTING RELAY PANELS
 PROJECT NO.: 0803 B
 DATE: 04/10/08
 SHEET NO.: 11 OF 11

E1.9

SIE Klingenstein
 5122 Riverchase Lane
 8000 Riverchase Blvd
 Springdale, Virginia 22154
 Phone: (703) 978-0100
 Fax: (703) 978-0101
 www.sie.com

5/20/08 10:58:31 AM