

WINDOW SCHEDULE (A)

MARK	SIZE	TYPE	FRAME	GLASS	LITES	ACCESSORIES	REMARKS
A	2/6 x 6/0	FIXED	ALUMINUM*	INSUL. LOW E	2/2	SCREEN SHUTTER	
		S. HUNG	WOOD	TEMPERED	2/4		
		D. HUNG		WIREFGLASS	6/6		
		HORIZ. SLIDE		NONE	SEE ELEV.		
		VERT. SLIDE			ALARM		
		CASED OPENING					
		STEEL					
		ALUMINUM*					
		WOOD					
		TINTED					
		INSUL. LOW E					
		TEMPERED					
		WIREFGLASS					
		NONE					
		SEE ELEV.					
		ALARM					
		SCREEN SHUTTER					

*ALL ALUMINUM FRAMES TO HAVE DARK BRONZE FINISH.

DOOR & HARDWARE SCHEDULE (X)

MARK	EXTERIOR DOOR	TYPE	FRAME	HINGE	LOCK	ACCESSORIES	REMARKS
1	PR. 3/0 x 7/0	SOLID WOOD	ALUMINUM	DBL SWING	BUTT 1-1/2 PR	WEATHERSTRIP	NOTE #7
2	3/0 x 6/8	HOLLOW METAL	WOOD	BURGLERPRF	SLIDING	WEATHERSTRIP	NOTE #7
3	PR. 3/0 x 6/8	POCKET DOOR	ALUMINUM	DBL SWING	BUTT 1-1/2 PR	WEATHERSTRIP	NOTE #7
4	2/0 x 6/8	STOREFRONT	WOOD	BURGLERPRF	SLIDING	WEATHERSTRIP	NOTE #7
5	3/0 x 6/8	CASED OPENING	ALUMINUM	DBL SWING	BUTT 1-1/2 PR	WEATHERSTRIP	NOTE #7
6	3/0 x 6/8	CASED OPENING	WOOD	BURGLERPRF	SLIDING	WEATHERSTRIP	NOTE #7
7	3/0 x 6/8	CASED OPENING	ALUMINUM	DBL SWING	BUTT 1-1/2 PR	WEATHERSTRIP	NOTE #7
8	PR. 3/0 x 6/8	CASED OPENING	WOOD	BURGLERPRF	SLIDING	WEATHERSTRIP	NOTE #7
9	3/0 x 6/8	CASED OPENING	ALUMINUM	DBL SWING	BUTT 1-1/2 PR	WEATHERSTRIP	NOTE #7
10	3/0 x 7/0	CASED OPENING	WOOD	BURGLERPRF	SLIDING	WEATHERSTRIP	NOTE #7

DOOR & HARDWARE NOTES:

- ALL GLAZING TO BE LAMINATED SAFETY GLASS.
- DOOR HINGES TO BE STANLEY FULL MORRISE STANDARD WEIGHT- BALL BEARING HINGES. STAINLESS STEEL WITH DARK BRONZE FINISH @ EXTERIOR & MATCHING DARK BRONZE FINISH ON STANDARD STEEL @ INTERIOR.
- PROVIDE LEVER HANDLE AND APPROVED LOCKSETS WITH MATCHING DARK BRONZE FINISH. TO BE SELECTED BY OWNER.
- COORDINATE KENING SCHEDULE WITH OWNER.
- DOOR STOPS TO BE EQUAL TO IVES NO. 436 OR 437, AS REQUIRED.
- WEATHER-STRIP & THRESHOLD FINISH TO COMPLEMENT OTHER HARDWARE.
- WD, DOOR, TRM, & BASE TO BE SELECTED BY OWNER.
- USE STANLEY HARDWARE COMPLETE POCKET DOOR MOUNTING SET - ITEM NO.405940. OR EQUAL.

WINDBORNE DEBRIS PROTECTION FASTENING SCHEDULE FOR WOOD STRUCTURAL PANELS

FASTENER TYPE	FASTENER SPACING		
	PANEL SPAN ≤ 4 FOOT	PANEL SPAN ≤ 6 FOOT	PANEL SPAN ≤ 8 FOOT
2-17" #5 WOOD SCREWS	16"	12"	9"
2-17" #8 WOOD SCREWS	16"	16"	12"

WINDOWS IN BUILDINGS LOCATED IN WIND BORNE DEBRIS REGIONS SHALL HAVE GLAZED OPENINGS PROTECTED FROM WINDBORNE DEBRIS. WOOD STRUCTURAL PANELS WITH A MIN. THICKNESS OF 7/16" AND A MAX. SPAN OF 8 FEET SHALL BE PERMITTED FOR OPENING PROTECTION IN ONE AND TWO STORY BUILDINGS. PANELS SHALL BE PRECUT TO COVER THE GLAZED OPENINGS WITH ATTACHMENT HARDWARE PROVIDED.

CROSS SECTION (G)

SCALE: 3/8"=1'-0"

EXTERIOR STUCCO SPECIFICATIONS:

- COMPLY WITH ASTM C-841 AND C-482. PROVIDE 3/4" OVERALL THICKNESS ON SELF-FURRING DIAMOND MESH GALVANIZED METAL LATH 3.4 LB. PER SQ. YARD. ON TYVER STUCCO WRAP. ATTACH LATH AT DIMPLES ONLY. WITH NON-CORROSIVE SCREWS.
- METAL LATH AND ALL ACCESSORIES TO BE EQUAL TO YAMICO. TO INCLUDE CORNER BEADS, CASING BEADS, BASE SCREWS, AND CONTROL JOINTS. ALL INSTALLED WITH NON-CORROSIVE SCREWS. ALL ACCESSORIES TO BE ZINC. ALL CORNERS TO BE MITERED.
- STUCCO TO BE INSTALLED IN THREE COATS: SCATCH, BROWN, AND FINISH. FINISH COAT TO BE ORIENTAL STUCCO WITH SAND FLOAT FINISH BY U.S. GYPSUM.
- COMPLY WITH MFR. AND INDUSTRY RECOMMENDATIONS. INSTALL LATH IN ACCORDANCE WITH ASTM C-1063.
- SUBMIT DATA / CUT SHEETS FOR ALL ITEMS IF REQUIRED.

THERMAL COMPONENT CRITERIA (U-FACTOR AND R-VALUE)

MAX. GLAZING U-FACTOR	MINIMUM INSULATION R-VALUE	CEILINGS	WALLS	FLOORS	BASEMENT WALLS	CRACK SPACE WALLS
.75	R-26	R-13	R-11	R-5	R-5	R-5

DETAILED BLDG. REQUIREMENTS:


- (MAIN WIND FORCE RESISTING COMPONENTS)
- THE DESIGN, FABRICATION AND ERECTION OF STRUCTURAL STEEL FOR BLDGS. AND STRUCTURES SHALL BE IN ACCORDANCE WITH EITHER THE AISC LOAD AND RESISTANCE FACTOR DESIGN SPECIFICATION FOR STRUCTURAL STEEL BLDGS. (AISC-LRFD), AISC SPECIFICATION FOR STRUCTURAL STEEL BLDGS. - ALLOWABLE STRESS DESIGN (AISC-ASD) OR AISC SPECIFICATION FOR THE DESIGN OF STEEL HOLLOW STRUCTURAL SECTIONS (AISC-HSS). WIND LOAD DESIGN OF 1.30 MPH.
- ROOF COVERING SHALL BE DESIGNED IN ACCORDANCE WITH THE REQUIREMENTS SET FORTH IN IRC 2006, SEC. 1507.
- PROTECTION OF OPENINGS IN ACCORDANCE WITH IRC 2006, SEC. 1609.1.4.
- 7/16" THICK STRUCTURAL WOOD PANELS AND ATTACHMENT HARDWARE SHALL BE PROVIDED FOR BUILDING OCCUPANCY. THE PANELS SHALL BE NUMBERED FOR EACH GLAZED OPENING AND SHALL BE STORED ON SITE PERMANENTLY (IBC 1609.1.4, EXCEPTION)

CONTRACTOR NOTE

EACH CONTRACTOR RESPONSIBLE FOR THE CONSTRUCTION OF A MAIN WIND-FORCE RESISTING COMPONENT OF THIS BLDG. SHALL SUBMIT A WRITTEN CONTRACTORS STATEMENT OF RESPONSIBILITY TO THE BLDG. OFFICIAL AND OWNER PRIOR TO COMMENCEMENT OF THE WORK ON THAT COMPONENT. (IBC 2006, SEC. 1706.1)

GENERAL NOTES

- INSULATION AND INSULATION ASSEMBLIES SHALL MEET THE REQUIREMENTS OF SECTION 719.
- A. CONCEALED INSULATION SHALL HAVE A FLAME SPREAD OF 0-25 AND SMOKE DEVELOPED INDEX OF 0-450. EXCEPT THAT IN COMBUSTIBLE WOOD FRAME CONSTRUCTION.
- B. FACING SHALL COMPLY WITH IRC 2006.
- PROVIDE 5/8" LANDING, LEVEL WITH FINISHED FLOOR. OUTSIDE EXTERIOR DOORS. THRESHOLDS SHALL BE NOT MORE THAN 1/2" IN HEIGHT AND SHALL BE BEVELLED IF MORE THAN 1/4". DIMENSIONS ARE TO CENTERLINE. FACE OF STUDS, CENTER OF COLUMNS, OR FACE OF VENEER.
- CONTRACTOR TO VERIFY ALL SITE CONDITIONS, BUILDING LOCATIONS, AND DIMENSIONS PRIOR TO CONSTRUCTION.
- MATERIALS SHALL BE NEW AND U.L. LISTED.
- NO WORK SHALL BE CONCEALED UNTIL APPROVED BY LOCAL INSPECTORS.
- CONSTRUCTION SHALL COMPLY WITH ALL PARISH, STATE AND LOCAL CODES.
- CONTRACTOR TO GUARANTEE WORK FOR ONE YEAR.
- CONTRACTOR SHALL FURNISH WATER AND POWER FROM EXISTING SOURCES.
- EXTERIOR CALK SHALL BE DOW-CORNING 790 SILICONE. INSTALL IN ACCORDANCE WITH MFR. REQ. COORDINATE WITH ARCHITECT/OWNER AS TO COLOR. INTERIOR CALK SHALL BE EQUAL TO DAP PAINTABLE LATEX WITH SILICONE.
- PAINT GRADE TO SHALL BE SHERWIN WILLIAMS OR EQUIVALENT. ALL WORK TO RECEIVE 3 COATS. COLOR SELECTION BY OWNER.
- PROVIDE CLEANUP ON A REGULAR BASIS. NO TRASH STORED IN BUILDING.
- ALL BATT INSULATION SHALL HAVE A CLASS 'A' (0-25) FLAME SPREAD IN COMPLIANCE WITH APPLICABLE CODE.
- USE 6" STUDS, OR 4" STAGGERED STUDS AT ALL PLUMBING WALLS.
- PROVIDE GALVANIZED METAL PAN WITH DRAIN AT WATER HEATER LOCATION.
- ALL CORNERS SHALL BE PROPERLY BRAZED FOR WIND LOADS. A 48" SHEATHING SHALL BE PROVIDED EVERY 20 FEET OF WALL LENGTH.
- FLOORING SHALL BE NON-SUP.
- FLOORING LOCKS ON DOORS IN MEANS OF EGRESS SHALL NOT REQUIRE THE USE OF A KEY, SPECIAL KNOWLEDGE, OR SPECIAL DEVICE TO OPEN IN THE DIRECTION OF EGRESS. ALL DOORS SHALL HAVE LEVER TYPE HANDLES.
- INTERIOR WALLS AND CEILINGS SHALL HAVE A FLAME SPREAD OF 0-200 AND A SMOKE DEVELOPMENT RATING OF 0-450.
- ALL WORK SHALL COMPLY WITH THE LATEST EDITION OF ALL LOCAL, STATE AND NATIONAL CODES COVERING THE TYPE OF WORK BEING PERFORMED.
- PROVIDE PORTABLE FIRE EXTINGUISHERS IN ACCORDANCE WITH NFPA 101.1. SEE APPENDIX 'E' OF NFPA 101 FOR DISTRIBUTION OF EXTINGUISHERS.
- ALL FIRE WALLS SHALL EXTEND TIGHT TO ROOF SHEATHING, AND BE SEALED WITH AN APPROVED FIRE CALK.
- ALL ELECTRICAL, MECHANICAL, AND PLUMBING MATERIALS PENETRATING FIRE WALLS SHALL BE FIRE CALKED. (PENETRATIONS THROUGH RATED CONSTRUCTION SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-E814.)
- SERVICE COUNTER SHALL HAVE A HCP ACCESSIBLE WRITING SURFACE. MAX. 36" FROM F.F. (ADAAG MANUAL 1998, PG-135)



DAMMON ENGINEERING, INC.

CHIEF ENGINEER
EMMETT DAMMON, P.E.

CHIEF ARCHITECT
ROBERT WILTSE

1095 FLORIDA AVENUE
SUDDLELL, LA, 70456
OFFICE: 985-649-5332
FAX: 985-641-5950

WWW.DAMMONENGINEERING.COM
EMAIL: DAMMONENG@BELLFLOWER.MT

ARCHITECTURE
ENGINEERING
STUDIES
PLANNING
INVESTIGATION
EXPERT WITNESS

EL-BETHEL PENTECOSTAL CHURCH

REV. EUGENE WELLINGTON
ALEN ROAD
SUDDLELL, LA

CROSS SECTION

REV: _____
SCALE: AS NOTED
JOB#: 1819A
DATE: 11-19-08
SHEET 11

A-2