




2 ARCHITECTURAL FLOOR PLAN
 SCALE: 1/4" = 1'-0"

GENERAL NOTES

1. INSULATION AND INSULATION ASSEMBLIES SHALL MEET THE REQUIREMENTS OF IBC 2012 SECTION 719
 - A. CONCEALED INSULATION SHALL HAVE A FLAME SPREAD OF 0-25 AND SMOKE DEVELOPED INDEX OF 0-450 EXCEPT THAT IN COMBUSTIBLE (WOOD FRAME) CONSTRUCTION:
 - B. FACING SHALL COMPLY WITH IBC 2012
2. ALL MATERIALS SHALL BE NEW AND UL LISTED
3. NO WORK SHALL BE CONCEALED UNTIL APPROVED BY LOCAL INSPECTORS
4. CONSTRUCTION SHALL COMPLY WITH ALL PARISH, STATE, AND LOCAL CODES
5. CONTRACTOR TO GUARANTEE WORK FOR ONE YEAR FROM DATE OF SUBSTANTIAL COMPLETION
6. CONTRACTOR SHALL FINISH WATER AND POWER FROM EXISTING SOURCES
7. EXTERIOR CALKING SHALL BE THICK CAULK
8. PAINT SHALL BE SURETY MILLING OR EQUIVALENT AND APPROPRIATE FOR THE SUBSTRATE AND FINISH RECOMMENDED BY PAINT MANUFACTURER. ALL WORK TO RECEIVE THREE COATS (ONE PRIMER COAT, TWO FINISH COATS) UNLESS OTHERWISE RECOMMENDED BY PAINT MANUFACTURER. COLORS TO BE SELECTED BY OWNER
9. PROVIDE CLEANUP ON A REGULAR BASIS. NO TRASH SHALL BE STORED NEAR BUILDING PREMISES
10. ALL BATT INSULATION SHALL HAVE A CLASS "X" (0-25) FLAME SPREAD IN COMPLIANCE WITH IBC 2012
11. USE 2X6 STUDS OR TWO 2X4 STAGGERED STUDS WITH 2X6 SILL PLATE AT ALL WALLS WHERE 4" PIPE IS INDICATED. SEE PLUMBING RISER DIAGRAM FOR PIPE SIZE
12. PROVIDE GALVANIZED METAL PAN WITH DRAIN AT ALL WATER HEATERS, FOR SLIP RESISTANCE
13. ALL FLOORING SHALL MEET OR EXCEED ADA GUIDELINES REQUIREMENTS
14. INTERIOR LOCKS ON DOORS IN MEANS OF EGRESS SHALL NOT REQUIRE THE USE OF A KEY, SPECIAL KNOWLEDGE, OR SPECIAL DEVICE TO OPEN IN THE DIRECTION OF EGRESS. ALL DOORS SHALL HAVE LEVER TYPE HANDLES
15. INTERIOR WALLS AND CEILING SHALL HAVE A FLAME SPREAD OF 0-200 AND A SMOKE DEVELOPMENT RATING OF 0-450
16. ALL WORK SHALL COMPLY WITH THE LATEST EDITION OF ALL LOCAL, STATE, AND NATIONAL CODES COVERING THE TYPE OF WORK BEING PERFORMED
17. PROVIDE PORTABLE FIRE EXTINGUISHERS IN ACCORDANCE WITH NFPA EXTINGUISHERS "E" OF NFPA 101 FOR DISTRIBUTION OF EXTINGUISHERS
18. ALL FIRE WALLS SHALL EXTEND TIGHT TO ROOF DECK AND BE SEALED WITH AN APPROVED FIRE CAULK
19. ALL ELECTRICAL, MECHANICAL, AND PLUMBING MATERIALS PENETRATING FIRE WALLS SHALL BE FIRE CALKED (PENETRATIONS THROUGH RATED CONSTRUCTION SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF FLAMES AND HOT GASES WHEN TESTED IN ACCORDANCE WITH ASTM-E814)
20. SERVICE COUNTERS SHALL HAVE AN ACCESSIBLE WRITING SURFACE IN COMPLIANCE WITH ADA/ANS ACCESSIBILITY GUIDELINES 2010 SECTION 902.3

| REVISIONS | | DATE |
|-----------|-------------|------|
| # | DESCRIPTION | |
| | | |
| | | |
| | | |



LOUISIANA & MISSISSIPPI

Chief Engineer: Brian Mistich, PE
 554 Old Spanish Trail
 Slidell, LA 70458

www.dammonengineering.com
 info@dammonengineering.com
 PH: 985.649.5832

PRO MULTIS
LACOMBE CHAPEL

1700 VORTIECH ROAD AND LA HAY 434
 LACOMBE, LOUISIANA 70445

JOB No: 2354 DATE: 12-19-18
 DRAWN BY: CKD CHECKED BY: CKD

SHEET TITLE:
 ARCHITECTURAL FLOOR PLAN

DRAWING NUMBER:
A101

SHEET No: 2 of 3