

PANEL SCHEDULE

PKT NO	THHN SIZE	LOAD DESCRIPTION	LOCATION	BREAKER AMP POLE	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION	LOCATION	THHN SIZE	PKT NO
1	#12	RECEPTACLES, EXTENSOR	20	1	400	20	RECEPTACLES, PRESSING ROOM	112	2	2
2	#12	RECEPTACLES, EQUIPMENT AND REFR ROOMS	20	1	440	20	RECEPTACLES, UTILITY OFFICE	112	4	4
3	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICES	112	6	6
4	#12	DEDICATED RECEPTACLE	20	1	1200	20	WORKING REFR ROOM	112	8	8
5	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLE, VHS REFR ROOM	112	10	10
6	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	12	12
7	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	14	14
8	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 1 AND OFFICE 2	112	16	16
9	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, COFFEE LOUNGE	112	18	18
10	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	DEDICATED RECEPTACLE	112	20	20
11	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	DEDICATED RECEPTACLE	112	22	22
12	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	24	24
13	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	26	26
14	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	28	28
15	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	30	30
16	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	32	32
17	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	34	34
18	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	36	36
19	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	38	38
20	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	40	40
21	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	42	42
22	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	44	44
23	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	46	46
24	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	48	48
25	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	50	50
26	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	52	52
27	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	54	54
28	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	56	56
29	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	58	58
30	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	60	60
31	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	62	62
32	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	64	64
33	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	66	66
34	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	68	68
35	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	70	70
36	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	72	72
37	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	74	74
38	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	76	76
39	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	78	78
40	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	80	80
41	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	82	82
42	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	84	84

PANEL SCHEDULE

PKT NO	THHN SIZE	LOAD DESCRIPTION	LOCATION	BREAKER AMP POLE	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION	LOCATION	THHN SIZE	PKT NO
1	#12	RECEPTACLES, EXTENSOR	20	1	400	20	RECEPTACLES, PRESSING ROOM	112	2	2
2	#12	RECEPTACLES, EQUIPMENT AND REFR ROOMS	20	1	440	20	RECEPTACLES, UTILITY OFFICE	112	4	4
3	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICES	112	6	6
4	#12	DEDICATED RECEPTACLE	20	1	1200	20	WORKING REFR ROOM	112	8	8
5	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLE, VHS REFR ROOM	112	10	10
6	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	12	12
7	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	14	14
8	#12	DEDICATED RECEPTACLE	20	1	1200	20	RECEPTACLES, OFFICE 1 AND OFFICE 2	112	16	16
9	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, COFFEE LOUNGE	112	18	18
10	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	DEDICATED RECEPTACLE	112	20	20
11	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	DEDICATED RECEPTACLE	112	22	22
12	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	24	24
13	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	26	26
14	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	28	28
15	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	30	30
16	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	32	32
17	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	34	34
18	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	36	36
19	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	38	38
20	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	40	40
21	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	42	42
22	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	44	44
23	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	46	46
24	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	48	48
25	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	50	50
26	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	52	52
27	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	54	54
28	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	56	56
29	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	58	58
30	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	60	60
31	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	62	62
32	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	64	64
33	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	66	66
34	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	68	68
35	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	70	70
36	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	72	72
37	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	74	74
38	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	76	76
39	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	78	78
40	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	80	80
41	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	82	82
42	#12	RECEPTACLES, VENDING AND REFR ROOM	20	1	1000	20	RECEPTACLES, OFFICE 2 AND LOBBY	112	84	84

ELECTRICAL LOAD SUMMARY

ENTERGY POWER COMPANY	PROJECT NAME: BOYD FAMILY FUNERAL HOME	PROJECT ADDRESS: 4800 DOWNMAN ROAD NEW ORLEANS, LOUISIANA	INTENDED USER: BOYD	REG SERV: 208 V	PHASE: 3	WIRING: 4
				SERV ENTR SIZE: 350 AMPS		
				HVAC TONNAGE: 26 TONS		
				LARGEST MOTOR: HP		
				NOTE: MOTORS ABOVE 20HP MAY REQUIRE REDUCED VOLTAGE STARTING AND ARE NEVER RECOMMENDED FOR USE IN 120/240V, 1Ø, 3Ø SERV/CE		
	TOTAL BUILDING SQ FT: 1000	SF (MULT OCCUPANCY)				
	INDIVIDUAL UNIT SQUARE FOOTAGE: SF (MULT OCCUPANCY)					
	INDIVIDUAL UNIT DESIGNATION: (MULT OCCUPANCY)					
	LOAD SOURCE	1Ø-KVA	3Ø-KVA	OR	1Ø-KN	3Ø-KN
	BUILDING LIGHTING	111				
	ELECTRIC WATER HEATING	0/0				
	HEAT PUMPS		4/0			
	SUPPLEMENTAL HEAT SYSTEMS		1/5			
	AIR COND CONDENSING UNITS	6/3				
	ELEC HEATING (PRIMARY) - AMPS	26				
	COOKING	N/A				
	REFRIGERATION	1/6				
	RECEPTACLES (STANDARD)	33/6				
	RECEPTACLES (COMPUTER)	0				
	TOTAL MOTORS (EXCLUDE HVAC)	0				
	EXTERIOR LIGHTING	1/0				
	MISCELLANEOUS - CEILING FANS	32/5				
	OTHER (POOL EQUIPMENT, TENANT)	0				

PANEL SCHEDULE

PKT NO	THHN SIZE	LOAD DESCRIPTION	LOCATION	BREAKER AMP POLE	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION	LOCATION	THHN SIZE	PKT NO
1	#12	LIGHTING, PRESSING ROOM AND CORRIDOR	20	1	1000	20	LIGHTING, RESTROOMS	112	2	2
2	#12	LIGHTING, RESTROOM AND OFFICES	20	1	1000	20	SPACE	112	4	4
3	#12	LIGHTING, CONNECTOR	20	1	800	20	LIGHTING, LOBBY	112	6	6
4	#12	LIGHTING, VENDING ROOM A	20	1	1000	20	LIGHTING, VENDING VENDING ROOM	112	8	8
5	#12	LIGHTING, VENDING ROOM B	20	1	1000	20	LIGHTING, VENDING ROOM	112	10	10
6	#12	LIGHTING, VENDING ROOM C AND CORREL LOUNGE	20	1	1600	20	LIGHTING, FRONT PORCH	112	12	12
7	#12	LIGHTING, SECOND FLOOR	20	1	1200	20	LIGHTING, ATTIC	112	1	