



City of Slidell Cross Connection Control Program



Notice to all Contractors, Developers, Plumbers, or any other
Person/s connecting to the City of Slidell Water System

A Cross Connection Control Permit must be obtained at the
Office of Building and Safety prior to connecting to the City's Water System.

1. **A Cross Connection Control Permit shall be obtained for each Backflow Device installed.**
2. **Thermal Expansion Devices shall be installed in accordance with the Louisiana State Plumbing Code when installing Backflow Devices.**
3. **All Backflow Devices shall be installed by a licensed plumber and as per Louisiana State Plumbing Code requirements.**
4. **All Backflow Devices shall be tested by a State Certified Water Supply Protection Specialist (WSPS) and a copy of the test results shall be provided to the City prior to the start-up of any water service.**
5. **The following are City recommended devices:**

Residential Irrigation (Recommended Devices)	Commercial (Recommended Devices)
Watts Series LF009 Reduced Pressure Assemblies	Watts Series LF009 Reduced Pressure Assemblies
Watts Lf008PCQT Vacuum Breakers	Watts 957 Reduced Pressure Assemblies
	Watts LF007 Double Check Valve Assemblies
	Watts Series 709DCDA Double Check Valve Assemblies (Fire Line)
	Watts Series 757DCVA Double Check Valve Assemblies (Fire Line)

NOTE: Proper Backflow Device selection is crucial to insure the protection of the City's water system. Should you have questions concerning device selection or need any information about Cross Connection Control please contact us at the number listed below.

City of Slidell Office of Public Utilities 985 646-4291 – Fax 985 646-4238