



**ADDENDUM NO. 2**

09 August 2012

Textron Marine & Land Systems  
Building #3 - 2<sup>nd</sup> Floor Renovations  
Building #3 - 1<sup>st</sup> Floor Renovations  
Building #4 - 1<sup>st</sup> Floor Renovations  
19401 Chef Menteur Hwy.  
New Orleans, LA 70129

1. Addendum No. 1, for “Building #3 – 2<sup>nd</sup> Floor Renovations” remains in effect.

This Addendum addresses Building #3 – 1<sup>st</sup> Floor Renovations, and Building 4 – 1<sup>st</sup> Floor Renovations. All three projects will now be combined in one bid.

2. Provide Bid to Textron Marine and Land Systems, 19401 Chef Menteur Highway, New Orleans, LA 70129, Attn: Mr. Kevin Boudreaux, by 3:30 p.m. August 13, 2012.

Bid to consist of a single price for all the work as shown on construction documents for:

Textron Marine and Land Systems, Building #3 - 2<sup>nd</sup> Floor Renovations, Plans dated 4/12/12 and Specifications dated 4/30/12, and Addendum No. 1; and

Textron Marine and Land Systems, Building #3 – 1<sup>st</sup> Floor Renovations, Plans dated 06/20/12 and Specifications dated 06/30/2012; and Textron Marine and Land Systems, Building #4 – 1<sup>st</sup> Floor, Plans dated 06/26/2012 and Specifications dated 06/30/2012, and Addendum No. 2,

All of the above prepared by Dammon Engineering, Inc.

Comply with Textron RFQ and Terms and Conditions, copies attached.

3. Bid to be on bid form in Specification Manual, signed by appropriate corporate officer, in sealed envelope with Project Title and General Contractor's license number on the exterior.
4. Bid Bond, Performance Bond, and Payment Bond not required.
5. Delete reference to “Advertisement for Bids” in Table of Contents and on Document 00020 “Professional Seals.”
6. Delete reference to Unit Prices in Table of Contents and on Document 00020 “Professional Seals.”
7. Disregard “Unit Prices Form.”
8. Corporate Resolution and Noncollusion Affidavit not required at this time.

9. Bldg. #4 - 1st Floor, Sheet A-1, Finish Schedule, Room #101, Wainscot: Should be noted as "NONE". Some plan sets call for PT wainscot in this room.
10. Bldg. #4 - 1<sup>st</sup> Floor, Sheet A-1, Window Mark "A": PT Wainscot to include wrapping into window recess covering sides of recess and sill.
11. Bldg. #4 - 1<sup>st</sup> Floor, Sheet A-3, Cafeteria Cabinet Detail: These units to be ten feet in length as shown on Sheet A-1. Adjust elevation and provide additional doors and drawers in typical widths as required.
12. Bldg. #4 - 1<sup>st</sup> Floor, Sheet E-1: Delete three new convenience outlets shown in Cafeteria.
13. Bldg. #4 - 1<sup>st</sup> Floor, Sheet E-1: Add seven new dedicated 20 amp outlets for vending machines as shown on Sheet A-1. Feed new outlets from new breakers in existing Panel LP-5C.
14. Bldg. #4 – First Floor, Sheet M-1, HVAC Unit Schedule, Item No. 1: Unit to be 15 ton in lieu of 10 ton shown. Note: This AHU to be served by two ten ton condensing units shown as "A" and "B" on the Mechanical Plan.
15. Bldg. #3 – 1<sup>st</sup> Floor, Sheet A-1, Floor Plan and Door & Hardware Schedule: Provide Panic Hardware at the following locations: Dr. Mk. 1 from Auditorium 105 to Corridor 100; two Dr. Mk. 2's from Activity Rm. 108 to Corridor 100; and Dr. Mk. E from Main Auditorium to Exterior. Modify or add removable center mullion to Dr. Mk. E as required to provide proper operation.