

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

1095 Florida Ave.
Slidell, LA 70458

P.O. Box 2830
Slidell, LA 70459

985-649-5832
FAX 985-641-5950

INSPECTION

July 6, 2010

Attn: Tax Assessor's Office
St. Tammany Parish Tax Assessors
701 North Columbia Street
Covington, Louisiana 70433

Re: Mike Saitta and Lisa Schell
35373 Pine Street Extension
Pearl River, La. 70452
Assessment # 132-807-3146

Type: Residential

History:

Mrs. Lisa Schell contacted Dammon Engineering to request an inspection of the above named property to verify that the Sheet Rock installed was made in China.

Structure:

One story/wood frame/concrete foundation/brick and stucco siding/composition shingles - residence located on 2.217 acres with a total square footage of 3,434.

Findings:

A visual inspection was conducted of the residence to determine the type of sheet rock that is installed.

Findings:

1. In the attic, the words "Made in China" are immediately and clearly visible on the back of the sheetrock.
2. All the visible copper lines have turned black.
3. Please see the attached pictures.

Conclusion:

It is our impression that all the same type of sheet rock (Made in China) was used for the walls and ceilings throughout the residence.

Sincerely,

Emmett G. (Pete) Dammon, P.E.