FILE NAME: J:_Office Workbench\2303 - Zeigler Tree Service\Drawings\Current Drawings\M100 - MECHANICAL SCHEMATIC.dwg PLOT DATE & TIME: Tuesday, May 28, 2019 at 4:13:18 PM



LEGEND

- SUPPLY AIR GRILLE
- RETURN AIR GRILLE
- EXHAUST FAN
- LIGHT/EXHAUST FAN FIXTURE
- THERMOSTAT
- SUPPLY AIR DUCT
- RETURN AIR DUCT
- DAMPER CONTROL
- ROUND FLEX DUCT, MAX. LENGTH 12'-0", MIN. R-6. PROVIDE MAN. DAMPER AT DIFFUSER CONNECTIONS. DUCT SIZE AS FOLLOWS:
  250 CFM TO 350 CFM = 9"
  200 CFM TO 250 CFM = 8"
  150 CFM TO 200 CFM = 7"
  100 CFM TO 150 CFM = 6"

SQUARE FOOTAGE INFO:

ENCLOSED BUILDING:	6,311 SQ. FT.
ENTRY CANOPY:	52 SQ. FT.
SIDE CANOPY:	800 SQ. FT.
REAR CANOPY:	1,060 SQ. FT.
TOTAL UNDERBEAM:	8,223 SQ. FT.

1 MECHANICAL SCHEMATIC
SCALE: 1/4" = 1'-0"

DAMMON ENGINEERING, INC.
LOUISIANA & MISSISSIPPI
www.dammonengineering.com
info@dammonengineering.com
PH: 985.649.5832
Chief Engineer: Brian Mistich, PE
554 Old Spanish Trail
Slidell, LA 70458

#	DESCRIPTION	DATE

REVISIONS

SEAL:

NEW OFFICE WAREHOUSE
ZEIGLER TREE #
TIMBER, CO.
LA HWY 1085 PIER CROSS DRIVE
MADISONVILLE, LA 70447

JOB No:	2383	DATE:	06-12-2019
DRAWN BY:	JAG/VA	CHECKED BY:	CKD

The above drawings and specifications, designs and arrangements represented thereby are and shall remain the property of Dammon Engineering, Inc. and no part thereof shall be used in whole or in part for any purpose whatsoever without the written permission of Dammon Engineering. Visual contact with these drawings or specifications shall constitute conclusive evidence of acceptance of these restrictions.

SHEET TITLE:
MECHANICAL SCHEMATIC, DETAILS & SCHEDULES

DRAWING NUMBER:
M100

SHEET No: 32 of 12