CLECO

ELECTRICAL LOAD INVENTORY

PROJECT NAME: OFFICE WAREHOUSE
PROJECT ADDRESS: 217 GENERAL PATTON
TOWN: MANDEVILLE

LOAD SOURCE	KVA	OR	KW
LIGHTING		OR	5.5
ELECTRICAL WATER HEATING		OR	5.0
HEAT PUMP		OR	0
SUPPLEMENTAL HEAT SYSTEM		OR	0
AIR CONDITIONING		OR	2.4
AIR HANDLING EQUIPMENT		OR	
ELECTRIC HEATING: (CIRCLE ONE) (PRIMARY) / SECONDARY		OR	3.6
COOKING		OR	0
REFIGERATION		OR	1.5
RECEPTACLES: COMPUTER		OR	
OTHERS		OR	5.9
MISCELLANEOUS		OR	6.5
OTHER: (LIST)		OR	
TOTAL MOTOR LOAD (EXCLUDING HVAC) **		OR	

**FOR MOTORS EXCEEDING 20 H.P.

LARGEST MOTOR SIZE: _____ H.P.
SERVICE VOLTAGE: 208/120 VOLTS
PHASE: (SINGLE OR THREE) 3 PHASE

BLDG. SQUARE FOOTAGE: 8000 SQ. FT.

A/C OR HEAT PUMP TOTAL TONS: 3 TONS

SERVICE ENTRANCE SIZE: 200 AMPS

INFORMATION PROVIDED BY:

SITE PLAN OR SKETCH IS REQUIRED SHOWING PREFERRED METERING POINT

NAME: ANTHONY PONCETI
COMPANY NAME: DAMMON ENGINEERING
PHONES: BUSINESS: (985) 649-5832
MOBILE: (985) 285-8008
FAX:
BEEPER:

FORM 1: ELECTRICAL LOAD INVENTORY

PLEASE RETURN TO CLECO REPRESENTATIVE