



St. Tammany Fire Protection District #1 - Fire Prevention Bureau

1358 Corporate Square Slidell La.
70458
PO Box 1149

Phone: 985-646-4387

Fax: 985-646-4864



This inspection is intended for your safety and the safety of the citizens of Louisiana. Your cooperation is greatly appreciated.

Occupancy: Edward Jones
Address: 2306 FRONT ST STE SUITE 1
Date of Inspection: 7/31/2019 10:00:00 AM
Type of Inspection: Inspection - Courtesy Walk Thru

Severity	Location	Code	Reason
1 Note		Deficiency Status	Met with contractor and discussed the separating wall on the South side of the suite not being a true fire wall. The wall does not need to be rated because the building is fully sprinklered. I spoke with the City building official who agreed. Have your architect submit an exemption to the LSFM showing as such. Continue with construction as per the LSFM stamped plans.

Inspection Result: Complied
Re-Inspection Date:
Completed By: Gaubert,Jason

Report Received By:
Duane Arbo
Report Created By:
Gaubert,Jason

R.S. 40:1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, of Title 40 of the Louisiana Revised Statutes of 1950, R.S. 50:1569 expected, shall be fined not more than five hundred dollars or imprisoned, for not more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished at the discretion of the court.