



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

February 28, 2018

Brian A. Mistich, P.E.  
Dammon Engineering, Inc.  
554 Old Spanish trail  
Slidell, LA 70458

Re: Terra Bella Class C Swimming Pool  
66, 455 Gal, 2, 237 Square Foot Pool with a Deck Area of ??? Square Foot, 7 HR Turn-over, at 158 GPM at 40.6 TDH, 111-Occupant Maximum Occupancy  
One Tanning Shelves and One Zero Depth Entry with a Total Area of 539 Square Foot  
Denham Springs, LA  
St. Tammany Parish

Dear Mr. Mistich:

Plans and specifications of the above named project have been reviewed. The plans are **DISAPPROVED** pending resolution of the following items which appear to be in conflict with applicable provisions of the Louisiana Administrative Code (LAC), or upon which further information is needed.

1. Please submit applicable pages of this office's "Engineering Services Permit Application."
2. Please specify the water and sewer system's name which the pool will be connected with in drawings. Additional comments may arise.
3. Please provide details for the proposed pedestal water feature. Additional comments may arise.
4. Please specify the chemicals that will be used for disinfection and the targeted chlorine residual which will be maintained in the pool. Also please specify the means of PH control for the proposed pool. Additional comments may arise.
5. Please provide the total deck area. Additional comments may arise.
6. Per LAC 51: XXIV. 317. D. 1, underwater seat benches are not allowed in pools. Variance request will be processed once other comments have been addressed.

Once we receive the information needed to comply with the above comments, the application will be entered into the plans tracking database and reviewed in the order it is received. If you have any questions or require additional information, please call me at (985) 543-4958.

Respectful,

February 28, 2018

Page 2 of 2

Re: Terra Bella Class C Swimming Pool  
St. Tammany Parish



Jie Gu, P.E.  
Region IX Engineer

cc: St. Tammany Parish Sanitarian Manager, LDH/OPH  
Michael Cuellar, E. I, LDH/OPH Region 9 Engine