

ATTN: JIM WAITE

# Dammon Engineering, Inc.

dammonengineering.com

1095 Florida Ave.  
Slidell, LA 70458

P.O. Box 2830  
Slidell, LA 70459

985-649-5832  
FAX 985-641-5950

December 19, 2006

Mr. Gene Bates  
Office of State Fire Marshal  
8181 Independence Blvd.  
Baton Rouge, LA 70806

RE IBC Review P0319133  
Wings Pizza N Things  
550 Gause Blvd.  
Slidell, LA 70458

LA. S.F.M. PLAN REVIEW  
 PO# 319133 REVIEWER \_\_\_\_\_  
 READING FILE DATE MO \_\_\_\_\_ YR \_\_\_\_\_  
 ORIG. TO: \_\_\_\_\_  
 SENDER \* APPL. \_\_\_\_\_ OWNER \_\_\_\_\_  
 CC'S \_\_\_\_\_  
 COPY WHAT PGS. all  
 B.R. \_\_\_\_\_ N.O. \_\_\_\_\_ ALEX \_\_\_\_\_ LAF. \_\_\_\_\_  
 SHREVE \_\_\_\_\_ HO FILE \_\_\_\_\_ HC DEPT \_\_\_\_\_  
 DET FILE \_\_\_\_\_ HR FILE \_\_\_\_\_ NON-REQ. SYST. \_\_\_\_\_  
 OTHER \_\_\_\_\_

DEAN BORN.  
SLIDELL BIDG OFFICIAL.

Dear Mr. Bates,

With regard to the above referenced project, the following information is provided:

The suite was inadvertently listed as "Suite A". Please be advised that Wings Pizza N Things will occupy "Suite 1"

### II Fire Protection Systems

- 1) Fire Resistant Materials and Construction

No information was provided about rating of demising walls. Please see the attached revised floor plan showing the demising wall is to be a 2 hour rated wall. The detail page A200 shows this wall using the UL 411 design and 2 hour rated. *ok.*

### VII Plumbing Systems

- 1) According to Table 407 the proposed facility requires a minimum of two water closets for each Men's and Women's restrooms. Please see the revised floor plan showing 3 water closets in each restroom.
- 2) No indication of a minimum of one drinking fountain. This facility is a restaurant and will offer free water to patrons. *ok.*

If you have any questions, please feel free to call.

Sincerely,

David Dammon  
Project Manager

*appears to comply*  
*JL Waite*  
*1-10-07*

RECEIVED

DEC 19 2006

STATE FIRE MARSHAL  
ARCHITECTURAL SECTION