



Inspection Report

Inspection Date: 9/18/2017 2:13:00 PM

PASSED

John Arnold should contact Jefferson Parish at
(504) 736-6957 for further information.

| Permit Number | Work Order ID | Inspection ID |
|---------------|---------------|---------------|
| 17-360548 | 8437263 | 4556147 |

| Jurisdiction | Inspection type | Inspector |
|--------------|----------------------|------------|
| Jefferson | Gas Final Inspection | Mirt Dugas |

| Customer | Address | Phone |
|-------------|--|-------|
| John Arnold | 5101 LAPALCO BLVD MARRERO, LA 70072 | |

| Scheduled | Completed | Uploaded |
|-----------------------|----------------------|----------------------|
| 9/18/2017 12:00:00 AM | 9/18/2017 2:13:00 PM | 9/18/2017 2:16:49 PM |

| Details |
|--|
| 3" line 1.6 mil. btu's 4 psi for 15 min valves vents connectors final ok |

The information included in this report is also available at
MyPermitNow.org

For more information on accessing your information through MyPermitNow.org's free Customer Portal,
Visit MyPermitNow.org, or contact our support line at 1-866-95-PERMIT (73764)