



STATE OF LOUISIANA
DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS
OFFICE OF STATE FIRE MARSHAL



CERTIFICATE OF COMPLETION

DATE: 12.22.10

SFM PROJECT PO 372882 SYSTEM TYPE Arch. CONTRACTOR SIGNATURE _____
 SFM PROJECT PO _____ SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____
 SFM PROJECT PO _____ SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____
 SFM PROJECT PO _____ SYSTEM TYPE _____ CONTRACTOR SIGNATURE _____

Please list all projects pertaining to the currently scheduled reviews of the building. System type refers to Architectural, Fire Alarm, Kitchen Hood/Wet Chemical Suppression, Fire Suppression, or Storage Tank.

To arrange for inspection of the project, please contact the district office two (2) to three (3) weeks in advance. To verify inspection district and phone number please refer to the "cc" list on the last page of the State Fire Marshal review letter. The plans stamped reviewed by this office must be available on job site at time of inspection. This Certificate Of Completion must be provided to the inspecting deputy at final inspection.

This is to certify the below project

PROJECT TITLE FROM APPLICATION <u>Child Development Council of Acadiana</u>		
PROJECT ADDRESS <u>Hwy 167</u>		
CITY <u>Opelousas</u>	STATE <u>LA</u>	ZIP CODE <u>70571</u>

was periodically observed by me, by my consultants, and/or by others in my employ during construction and, to the best of my knowledge, information and belief, has been completed in accordance with the safety provisions which were shown in the plans and specifications previously reviewed by the Fire Marshal.

UNDER PENALTY OF LAW FOR FALSE STATEMENTS, I (NAME OF ARCHITECT/ENGINEER IF REQUIRED, OTHERWISE OWNER)

PRINT NAME Robert Wiltse SIGNATURE [Signature]

ARCHITECT/ CIVIL ENGINEER LICENSE NUMBER 2736

CERTIFY ALL STATEMENTS CONTAINED HEREIN ARE, TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF, TRUE AND CORRECT.

LAC 55:V:307 OBSERVATION OF CONSTRUCTION

A. For a structure which by law may only be constructed with plans prepared and certified by a licensed architect or civil engineer, it shall be the duty of the owner of such a structure to provide for periodic observation of the construction of the structure to determine if the work is proceeding in accordance with the plans and specifications as approved by the fire marshal. The observations shall be performed by a registered architect or a registered civil engineer.

B. Upon completion of such work, where the law requires the owner to engage an architect or registered civil engineer, the owner shall furnish to the fire marshal a certificate signed by a registered architect or registered civil engineer stating that the periodic observations have been made and that to the best of the architect's or engineer's knowledge, information and belief, the work was completed in accordance with those fire safety standards and regulations stipulated in the plans and specifications previously approved by the fire marshal. When the owner has not engaged an architect or registered civil engineer, and the same is not required by law, the owner must submit the certificate of completion when appropriate, but always under his signature.

C. Occupancy of a structure, watercraft or movable prior to furnishing a certificate to the fire marshal as required under this regulation is expressly forbidden by the fire marshal, unless and until a satisfactory inspection has been made by the fire marshal or his certified representative.

D. In order to comply with the requirements of §307.B, the owner must submit to the fire marshal the following certificate completed by the architect, civil engineer, or, if neither is required by law, the owner.



STATE OF LOUISIANA

OFFICE OF STATE FIRE MARSHAL, CODE ENFORCEMENT, AND BUILDING SAFETY INSPECTION REPORT

This inspection is intended for your safety and the safety of the citizens of Louisiana. Your cooperation is greatly appreciated.

District: **ALEX-LAFAYETTE**

Event Code: **523961-2**

STRUCTURE ID. 265728	OCCUPANCY 26	EXT. NO	PARISH 49	BLDG. 2	STORIES 1	# INSP. 2	BADGE 395	SCHED. INSP. DATE 01/26/2011	INSP. TYPE RE	ACT. INSP. DATE 01/19/2011	BEGIN TIME 10:24 AM
CONST. TYPE 5000	FACILITY CODE Z-9999999	PROJECT ID. 372882-1	PROJECT TYPE ARCH	<input checked="" type="checkbox"/> COKE DET <input type="checkbox"/> PARTL <input type="checkbox"/> COMP <input type="checkbox"/> NONE		<input type="checkbox"/> AUTO SPRK <input type="checkbox"/> PARTL <input type="checkbox"/> COMP <input checked="" type="checkbox"/> NONE		<input type="checkbox"/> FIRE ALARM <input type="checkbox"/> PARTL <input type="checkbox"/> COMP <input checked="" type="checkbox"/> NONE		AUTO SPRK	CAPACITY
ANNIVERSARY DATE		YEAR BUILT 2010	SQ. FOOTAGE 9900							BLDG. POWER <input type="checkbox"/> GAS <input checked="" type="checkbox"/> ELECTRIC	
TRADE						OWNER					
NAME CHILD DEVELOPMENT COUNCIL OF ACADIANA						NAME BARBARA PICKNEY					
ADDRESS HWY 167						ADDRESS PO DRAWER 910					
CITY OPELOUSAS			STATE LA			CITY OPELOUSAS			STATE LA		
ZIP 70571-		PHONE NOVE				ZIP 70571-		PHONE 337-942-9669			
CODE SECTION	REQUIREMENTS (CODE VIOLATIONS)										CORRECTION DATE
(Comment)	NO APPARENT DEFICIENCIES AT TIME OF INSPECTION										
	C										
	OF C ON FILE										
	NFPA 70 110.22 Identification of Disconnecting										
	Means. [COMPLIED]										
	314.20 In Wall or Ceiling. [COMPLIED]										
	ADAAG:4.19.4 Exposed Pipes and Surfaces.										
	[COMPLIED]										
	4.13.9* Door Hardware. [COMPLIED]										
Signature and Title of person to whom requirements were explained. <i>Richard Miller</i> Richard Miller						I, DERRELSSELLERS hereby certify that this is a true report as a result of my inspection. SIGNATURE OF INSPECTOR <i>Derrell Sellers</i>				TIME OUT 11:00 AM	
R.S. 40:1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, of Title 40 of the Louisiana Revised Statutes of 1950, R.S. 40:1569 excepted, shall be fined not more than five hundred dollars or imprisoned, for not more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished as such at the discretion of the court.											

SEE LAST PAGE OF ORDER FOR RIGHTS OF APPEAL.