



DAMMON
ENGINEERING, INC.

CHIEF ENGINEER
EMMETT
DAMMON, P.E.
CHIEF ARCHITECT
ROBERT
WILTSE

1095 FLORIDA AVENUE
SLIDELL, LA. 70458
OFFICE: 985-643-5832
FAX: 985-641-5950

WWW.DAMMONENGINEERING.COM
WEBSITE:
EMAIL:
DAMMONEN@BLSOUTH.NET

ARCHITECTURE
ENGINEERING
PLANNING
STUDIES
INVESTIGATION
EXPERT WITNESSES

NEW OFFICE
COMPLEX

CHILD DEVELOPMENT
COUNCIL OF
ACADIANA, INC.
OPELOUSAS, LA

ELECT. PANEL
SCHEDULES

REV:
SCALE: AS NOTED
JOB#: 2030
DATE: 7-14-09
SHEET

E-4

PANEL: MDP
LOCATION: ELECT. RM 128
FEEDER SOURCE: MDP
VOLTAGE: 120/208V, 600A 3φ, 4W
M.C.B. S/N SURFACE MOUNTED, 22,000 A.I.C.

NO.	TYPE	LOAD DESCRIPTION	RECIPIER	LOAD (VA)	POLE	APF	LOCATION	TYPE	NO.
1	-	BLANK	-	-	-	-	-	-	2
2	-	BLANK	-	-	-	-	-	-	3
3	-	BLANK	-	-	-	-	-	-	4
4	-	BLANK	-	-	-	-	-	-	5
5	-	BLANK	-	-	-	-	-	-	6
6	-	BLANK	-	-	-	-	-	-	7
7	-	BLANK	-	-	-	-	-	-	8
8	-	BLANK	-	-	-	-	-	-	9
9	-	BLANK	-	-	-	-	-	-	10
10	-	BLANK	-	-	-	-	-	-	11
11	-	BLANK	-	-	-	-	-	-	12
12	-	BLANK	-	-	-	-	-	-	13
13	-	BLANK	-	-	-	-	-	-	14
14	-	BLANK	-	-	-	-	-	-	15
15	-	BLANK	-	-	-	-	-	-	16
16	-	BLANK	-	-	-	-	-	-	17
17	-	BLANK	-	-	-	-	-	-	18
18	-	BLANK	-	-	-	-	-	-	19
19	-	BLANK	-	-	-	-	-	-	20
20	-	BLANK	-	-	-	-	-	-	21
21	-	BLANK	-	-	-	-	-	-	22
22	-	BLANK	-	-	-	-	-	-	23
23	-	BLANK	-	-	-	-	-	-	24
24	-	BLANK	-	-	-	-	-	-	25
25	-	BLANK	-	-	-	-	-	-	26
26	-	BLANK	-	-	-	-	-	-	27
27	-	BLANK	-	-	-	-	-	-	28
28	-	BLANK	-	-	-	-	-	-	29
29	-	BLANK	-	-	-	-	-	-	30
30	-	BLANK	-	-	-	-	-	-	31
31	-	BLANK	-	-	-	-	-	-	32
32	-	BLANK	-	-	-	-	-	-	33
33	-	BLANK	-	-	-	-	-	-	34
34	-	BLANK	-	-	-	-	-	-	35
35	-	BLANK	-	-	-	-	-	-	36
36	-	BLANK	-	-	-	-	-	-	37
37	-	BLANK	-	-	-	-	-	-	38
38	-	BLANK	-	-	-	-	-	-	39
39	-	BLANK	-	-	-	-	-	-	40
40	-	BLANK	-	-	-	-	-	-	41
41	-	BLANK	-	-	-	-	-	-	42
				TOTAL CONNECTED LOAD (VA)	40-11000	30-00000	0-00000	GROUND BUS (V)	

PANEL: LA
LOCATION: ELECT. RM 128
FEEDER SOURCE: MDP
VOLTAGE: 120/208V, 150A 3φ, 4W
M.C.B. S/N SURFACE MOUNTED, 22,000 A.I.C.

NO.	TYPE	LOAD DESCRIPTION	RECIPIER	LOAD (VA)	POLE	APF	LOCATION	TYPE	NO.
1	-	BLANK	-	-	-	-	-	-	2
2	-	BLANK	-	-	-	-	-	-	3
3	-	BLANK	-	-	-	-	-	-	4
4	-	BLANK	-	-	-	-	-	-	5
5	-	BLANK	-	-	-	-	-	-	6
6	-	BLANK	-	-	-	-	-	-	7
7	-	BLANK	-	-	-	-	-	-	8
8	-	BLANK	-	-	-	-	-	-	9
9	-	BLANK	-	-	-	-	-	-	10
10	-	BLANK	-	-	-	-	-	-	11
11	-	BLANK	-	-	-	-	-	-	12
12	-	BLANK	-	-	-	-	-	-	13
13	-	BLANK	-	-	-	-	-	-	14
14	-	BLANK	-	-	-	-	-	-	15
15	-	BLANK	-	-	-	-	-	-	16
16	-	BLANK	-	-	-	-	-	-	17
17	-	BLANK	-	-	-	-	-	-	18
18	-	BLANK	-	-	-	-	-	-	19
19	-	BLANK	-	-	-	-	-	-	20
20	-	BLANK	-	-	-	-	-	-	21
21	-	BLANK	-	-	-	-	-	-	22
22	-	BLANK	-	-	-	-	-	-	23
23	-	BLANK	-	-	-	-	-	-	24
24	-	BLANK	-	-	-	-	-	-	25
25	-	BLANK	-	-	-	-	-	-	26
26	-	BLANK	-	-	-	-	-	-	27
27	-	BLANK	-	-	-	-	-	-	28
28	-	BLANK	-	-	-	-	-	-	29
29	-	BLANK	-	-	-	-	-	-	30
				TOTAL CONNECTED LOAD (VA)	40-14000	30-11000	0-00000	GROUND BUS (V)	

PANEL: RA
LOCATION: ELECT. RM 128
FEEDER SOURCE: MDP
VOLTAGE: 120/208V, 150A 3φ, 4W
M.C.B. S/N SURFACE MOUNTED, 22,000 A.I.C.

NO.	TYPE	LOAD DESCRIPTION	RECIPIER	LOAD (VA)	POLE	APF	LOCATION	TYPE	NO.
1	-	RECEPTACLES - RM 104	20	1000	1	1.000	RECEPTACLES - RM 106	#12	2
2	-	RECEPTACLES - RM 104	20	1000	1	1.000	RECEPTACLES - RM 106	#12	3
3	-	RECEPTACLES - RM 105	20	1000	1	1.000	RECEPTACLES - RM 106	#12	4
4	-	RECEPTACLES - RM 105	20	1000	1	1.000	RECEPTACLES - RM 106	#12	5
5	-	RECEPTACLES - RM 105	20	1000	1	1.000	RECEPTACLES - RM 106	#12	6
6	-	RECEPTACLES - RM 107	20	1000	1	1.000	RECEPTACLES - RM 106	#12	7
7	-	RECEPTACLES - RM 107	20	1000	1	1.000	RECEPTACLES - RM 106	#12	8
8	-	RECEPTACLES - RM 107	20	1000	1	1.000	RECEPTACLES - RM 106	#12	9
9	-	RECEPTACLES - RM 107	20	1000	1	1.000	RECEPTACLES - RM 106	#12	10
10	-	RECEPTACLES - RM 107	20	1000	1	1.000	RECEPTACLES - RM 106	#12	11
11	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	12
12	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	13
13	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	14
14	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	15
15	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	16
16	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	17
17	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	18
18	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	19
19	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	20
20	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	21
21	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	22
22	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	23
23	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	24
24	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	25
25	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	26
26	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	27
27	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	28
28	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	29
29	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	30
30	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	31
31	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	32
32	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	33
33	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	34
34	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	35
35	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	36
36	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	37
37	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	38
38	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	39
39	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	40
40	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	41
41	-	RECEPTACLES - RM 103	20	1000	1	1.000	RECEPTACLES - RM 106	#12	42
				TOTAL CONNECTED LOAD (VA)	40-20000	30-21000	0-10000	GROUND BUS (V)	

PANEL: YD
LOCATION: SOUTHSIDE KITCHEN WALL
FEEDER SOURCE: MDP
VOLTAGE: 120/208V, 150A 3φ, 4W
M.C.B. S/N SURFACE MOUNTED, 22,000 A.I.C.

NO.	TYPE	LOAD DESCRIPTION	RECIPIER	LOAD (VA)	POLE	APF	LOCATION	TYPE	NO.
1	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	2
2	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	3
3	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	4
4	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	5
5	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	6
6	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	7
7	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	8
8	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	9
9	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	10
10	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	11
11	-	RECEPTACLES - KITCHEN	20	1800	1	1.000	RECEPTACLES - KITCHEN	#12	12
12	-	RECEPTACLES - KITCHEN							