

GENERAL NOTES THIS SHEET:

- 1. EXISTING DUCTWORK SHOWN DASHED.
- 2. EXISTING DUCTWORK TO BE REMOVED SHOWN HATCHED, CAP WHERE INDICATED.
- 3. ALL MECHANICAL TO REMAIN UNLESS NOTED OTHERWISE.

SPECIFIC NOTES THIS SHEET:

- ① EXISTING AC UNIT ABOVE CEILING TO REMAIN.
- ② REMOVE EXISTING SPRINKLER. HEADS MAY BE REUSED IF POSSIBLE.
- ③ REMOVE EXISTING THERMOSTAT AND LOCK BOX. SEE M-4 FOR NEW LOCATION.
- ④ REMOVE EXISTING R/A TRANSFER DUCT AND ASSOCIATED DUCTWORK.
- ⑤ EXISTING FILTER RETURN TO REMAIN. ADJUST FOR NEW GRID.

